

P R E P A R E D   B Y



# Hydrologic and Hydraulic Modeling: Operations Model

Pensacola Hydroelectric Project  
Project No. 1494

Updated Study Report

September 2022

## Table of Contents

Executive Summary .....	iii
List of Abbreviations and Terms .....	iv
1. Introduction and Background.....	1
1.1 Project Description.....	1
1.2 Study Plan Proposals and Determination.....	2
1.3 Vertical Datums.....	3
2. USACE RiverWare Model .....	3
3. Flood Routing Model .....	6
3.1 Input Data .....	6
3.2 Methodology .....	6
4. Operations Model .....	7
4.1 Input Data and Preparation.....	7
4.1.1 Headloss vs. Turbine Discharge.....	7
4.1.2 Stage-Area-Storage Tables .....	9
4.1.3 Turbine Efficiency .....	9
4.1.4 Turbine Maximum Discharge.....	10
4.1.5 Tailwater Rating Curves .....	10
4.1.6 Unit Outages.....	10
4.1.7 Dissolved Oxygen Air Valves.....	10
4.1.8 Electricity Prices .....	11
4.1.9 Spillway Capacity.....	11
4.2 Methodology .....	11
5. Validation.....	13
5.1 Validation Results: Flood Routing Model.....	13
5.2 Validation Results: Operations Model .....	18
5.3 Validation Against USGS Gage Data .....	20
5.4 Post-Validation Model Improvements .....	21
5.4.1 Flood Routing Model Ramping Rate Restrictions.....	21
5.4.2 Operations Model Turbine Shutoff Compensation .....	21
5.4.3 Flood Routing Model Stage Matching .....	22
5.4.4 Updated Stage-Area-Storage Table .....	23
6. Scenarios Computed for H&H and Sedimentation Studies.....	24
6.1 Single Events for CHM, Baseline Operations.....	24
6.2 Single Events for CHM, Anticipated Operations .....	25
6.3 50-year Simulations for STM .....	27

6.4	Single Events for 1D UHM, Anticipated Operations .....	28
7.	Scenarios Computed for Other Studies.....	28
7.1	Aquatic Species Study .....	29
7.2	Terrestrial Species Study.....	29
7.3	Wetlands and Riparian Habitat Study.....	29
7.4	Recreation and Navigation .....	29
8.	Summary .....	30
9.	References .....	31

## List of Figures

Figure 1.	Operations Model Study Area.....	1
Figure 2.	Datum Transformations and Conversions .....	3
Figure 3.	RiverWare Model Domain.....	5
Figure 4.	Flood Routing Model Validation Period of Record.....	14
Figure 5.	Van Buren Guide Curve.....	15
Figure 6.	Modeled July 2007 Pensacola Elevations .....	16
Figure 7.	RiverWare vs. Flood Routing Model Oscillation Comparison.....	16
Figure 8.	RiverWare Model vs. Flood Routing Model Correlation Plots at Pensacola .....	17
Figure 9.	RiverWare Model vs. Flood Routing Model Correlation Plots at Kerr .....	17
Figure 10.	Operations Model Validation Period of Record .....	18
Figure 11.	RiverWare Model vs. Operations Model Correlation Plots at Pensacola .....	19
Figure 12.	RiverWare Model vs. Operations Model Correlation Plots at Kerr .....	19
Figure 13.	Validation Against USGS Gage Data, October 2009 .....	20
Figure 14.	Validation Against USGS Gage Data, December 2015 .....	21
Figure 15.	Minimum Threshold Price for Generation (Anticipated Operations).....	26

## Appendices

Appendix A – USACE RiverWare Data

Appendix B – Operations Model Input Data

## Executive Summary

Mead & Hunt, Inc. (Mead & Hunt) is assisting Grand River Dam Authority (GRDA) with its intent to relicense the Pensacola Hydroelectric Project (Project), which is regulated by the Federal Energy Regulatory Commission (FERC). Flood control operations at the Project are regulated by the United States Army Corps of Engineers (USACE). GRDA proposed certain hydraulic and operations models for the relicensing study. The FERC's study plan determination requires GRDA to prepare an Updated Study Report (USR). Mead & Hunt has performed this task on behalf of GRDA. This report documents the updated results related to the Operations Model (OM) to be presented at the USR meeting.

USACE's RiverWare period-of-record model is a tool used by USACE Southwestern Division, Tulsa District (SWT) to simulate reservoir operations on the Arkansas River system upstream of United States Geological Survey (USGS) gage number 07250500 at Van Buren, Arkansas, including the Project. This model uses a daily time step and includes over 30 reservoirs.

Mead & Hunt developed a Flood Routing Model (FRM) for GRDA to replicate, as closely as possible, the Project flow routing decisions in the USACE RiverWare period-of-record model (RWM) as an input to the OM. The FRM is needed to investigate hypothetical events and operating scenarios that would be difficult and time-consuming to program into the RWM. The FRM includes three reservoirs (Pensacola, Kerr, and Fort Gibson), which operate as a subsystem for flow routing, and uses daily time steps like the RWM.

Mead & Hunt developed an OM for GRDA to simulate flow routing, hydropower scheduling, and other constraints on an hourly time step to support the Project relicensing effort. Because electricity prices vary widely within a day, hourly time steps provide improved accuracy for hydropower operations simulation. Output from the FRM – most importantly the average daily total discharge – is used as an input to the OM. The OM seeks to optimize the hydropower generation revenue at each facility while simultaneously satisfying various physical and operational constraints, including the flow routing decisions based on the RWM model as simulated in the FRM. The OM includes Pensacola Dam and Kerr Dam (Markham Ferry Hydroelectric Project), which is downstream of Pensacola Dam. Both Pensacola Dam and Kerr Dam are owned and operated by GRDA, and flow routing decisions at both projects are regulated by USACE under certain conditions.

The FRM and OM were validated against the RWM using the common metrics of the Coefficient of Determination ( $R^2$ ) and the Nash-Sutcliffe Efficiency (NSE) to evaluate modeled total discharge and elevation. The OM was also validated by comparing the water surface elevation (WSEL) results to USGS gage data upstream of Pensacola Dam for two historical events recommended by the FERC. Sensitivity of OM results to stage-area-storage table updates were calculated.

The OM was used to simulate the reservoir levels resulting from different combinations of starting elevations, flow events, existing and future stage-storage relationships, and baseline or anticipated operation scenarios. The OM was also used to simulate the effects of changing elevation-storage relationships over time in support of the Sediment Transport Model (STM). Lastly, the OM was also used to simulate the effects of anticipated operations on reservoir water levels in support of the aquatic species study, terrestrial species study, wetlands and riparian habitat study, and assessment of recreation navigation impacts.

## List of Abbreviations and Terms

1D.....	One-Dimensional
AFRC.....	Allowable Falling Release Change
CADSWES .....	Center for Advanced Decision Support for Water and Environmental Systems
CFR.....	Code of Federal Regulations
CFS.....	Cubic Feet Per Second
CHM.....	Comprehensive Hydraulic Model
DO.....	Dissolved Oxygen
EEC.....	English Electric Company Limited
GRDA.....	Grand River Dam Authority
FERC.....	Federal Energy Regulatory Commission
FRM.....	Flood Routing Model
H&H Study.....	Hydrologic and Hydraulic Modeling Study
ISR .....	Initial Study Report
kW.....	kilowatt
MWh.....	Megawatt-hour
NAVD88 .....	North American Vertical Datum of 1988
NGVD29.....	National Geodetic Vertical Datum of 1929
NSE.....	Nash-Sutcliffe Efficiency
OAC.....	Oklahoma Administrative Code
OM.....	Operations Model
PD .....	Pensacola Datum
POR.....	Period of Record
Project .....	Pensacola Hydroelectric Project
PSP .....	Proposed Study Plan
R <sup>2</sup> .....	Coefficient of Determination
RSP .....	Revised Study Plan
RWM .....	RiverWare Model
SPD.....	Study Plan Determination
STM.....	Sediment Transport Model
SWT .....	Southwestern Division, Tulsa District
TW .....	Tailwater
UHM .....	Upstream Hydraulic Model
USACE.....	United States Army Corps of Engineers
USGS .....	United States Geological Survey
USR.....	Updated Study Report
VBA .....	Visual Basic for Applications

## 1. Introduction and Background

### 1.1 Project Description

The Pensacola Hydroelectric Project is owned and operated by GRDA and regulated by the FERC. Pensacola Dam is located in Mayes County, Oklahoma on the Grand-Neosho River. Pensacola Dam impounds Grand Lake. Construction of Pensacola Dam was completed in 1940. Authorized purposes for the Project include flood control, recreation, and hydropower. **Figure 1** displays the study area. Downstream of Pensacola Dam, GRDA also owns and operates the Robert S. Kerr Dam as the Markham Ferry Hydroelectric Project. Kerr Dam is also in Mayes County and impounds Lake Hudson, also known as the Markham Ferry Reservoir. Flow routing decisions at both Pensacola Dam and Kerr Dam are regulated by USACE under certain conditions.




Figure 1. Operations Model Study Area

## **1.2 Study Plan Proposals and Determination**

GRDA is currently in the relicensing of the Project. The timeline of study plan proposals and determination is as follows:

1. On April 27, 2018, GRDA filed its Proposed Study Plan (PSP) to address hydrologic and hydraulic modeling in support of its intent to relicense the Project.
2. On September 24, 2018, GRDA filed its Revised Study Plan (RSP).
3. On November 8, 2018, the FERC issued its Study Plan Determination (SPD) for the Project.
4. On January 23, 2020, the FERC issued an Order on the Request for Clarification and Rehearing, which clarified the timeline for certain milestones applicable to the relicensing study plan.
5. On September 30, 2021, GRDA filed its Initial Study Report (ISR).
6. On February 24, 2022, the FERC issued its Determination on Requests for Study Modifications and New Studies for the Project.
7. On May 27, 2022, the FERC issued its Determination on Requests for Study Modifications for the Pensacola Hydroelectric Project, related to the Sedimentation Study plan.
8. On September 30, 2022, GRDA filed this report, the USR.

The PSP and RSP recommended the development of an OM to synthesize and create events that inform or set boundaries for the Comprehensive Hydraulic Model (CHM). The FERC's SPD included the following determination specific to the OM:

*We recommend that GRDA demonstrate in the ISR [Initial Study Report, filed September 2021] that it has validated its model results against the RiverWare output.*

The FERC's SPD and Order on Request for Clarification and Rehearing included direction to provide a model input status report by March 30, 2021 and hold a conference call on model inputs and calibration within 30 days of the input status report. The Operations Model Input Status Report was filed with FERC and shared with stakeholders on March 30, 2021 (Mead & Hunt, 2021). A Technical Conference was held on April 21, 2021, to allow relicensing participants to ask questions regarding the Model Input Status Report (MISR). GRDA's ISR was a continuation of the MISR and incorporated comments provided on the MISR. The ISR documented the development of the OM. On April 20, 2022 a Technical Conference was held to allow relicensing participants to ask questions regarding the Operations Model, discuss planned improvements to the model, and present the results of two historical validation cases recommended by the FERC.

FERC's February 2022 Determination recommended the following modifications relevant to the OM portion of the H&H modeling study:

1. Run the OM to simulate all inflow events with starting reservoir surface elevations of 734 feet to 757 feet PD.
2. Compare water surface elevations observed at the USGS gage on the upstream side of the dam to simulated stage hydrographs for the December 2015 and October 2009 inflow events.
3. Run a sensitivity analysis on the effect of switching to the most recent (i.e., 2019) bathymetry data in the OM.

This report documents the development of the FRM and OM, the validation of results against the RWM

output, and the implementation of the OM to provide results in support of the CHM and other relicensing studies. As documented in this USR, GRDA has completed FERC's requested modifications.

### 1.3 Vertical Datums

Data sources for this study use a variety of vertical datums. Unless otherwise noted, data related to Pensacola Dam and Grand Lake is referenced to the Pensacola Datum (PD) and data related to Kerr Dam and Lake Hudson is referenced to the National Geodetic Vertical Datum of 1929 (NGVD29). To convert from PD to NGVD29, add 1.07 feet. To convert from NGVD29 to the North American Vertical Datum of 1988 (NAVD88), add 0.33 feet. **Figure 2** displays datum transformations and conversions (Hunter, Trevisan, Villa, & Smith, 2020).




Figure 2. Datum Transformations and Conversions

Source: (Hunter, Trevisan, Villa, & Smith, 2020).

## 2. USACE RiverWare Model

The RWM is a tool used by USACE Southwestern Division, Tulsa District to simulate reservoir operations on the Arkansas River system upstream of USGS gage no. 07250500 at Van Buren, Arkansas (USACE, 2020). The model simulates hydrologic inflows, evaporation, seepage, water deliveries, reservoir management, flood control, and hydropower production on a daily time step from 1940 through 2019. The model area includes more than 30 reservoirs, and the main control point for flood routing decisions is at the Van Buren gage. When flows at Van Buren are projected to exceed the seasonal guide curve, upstream reservoirs store water to limit flow at Van Buren. Other reservoirs or reservoir subsystems also have their own flood release restrictions. Reservoir balance levels throughout the system are managed to limit flooding systemwide.

Under Section 7 of the Flood Control Act of 1944 (CFR, 1944), the USACE has the responsibility to prescribe releases from Pensacola Dam and Kerr Dam under active or anticipated flood conditions (CFR,

1945). The USACE may exercise direct control over the facilities or provide instructions to GRDA to manage releases for the purpose of basin-wide flood mitigation. The RWM illustrates how reservoir levels at Pensacola Dam and Kerr Dam may be increased during a large flood event impacting Van Buren, not because the spillway capacity or downstream channel capacity is exceeded at either facility, but because water is held back to limit flow at Van Buren.

USACE SWT provided Mead & Hunt, Inc. (Mead & Hunt) with time series, tabular, and other data from the RWM, and examples of these data are included in **Appendix A**. The model domain is shown in **Figure 3**.

Mead & Hunt downloaded the RiverWare Technical Documentation from the Center for Advanced Decision Support for Water and Environmental Systems (CADSWES) at University of Colorado Boulder, College of Engineering and Applied Science website and referenced it to understand how to replicate the modeling methods applicable to this study (CADSWES, 2020). CADSWES develops RiverWare, a river and reservoir/hydropower planning and management tool that is licensed by the University of Colorado Technology Transfer Office, and widely used by agencies and consultants. Documentation for the related TAPER model was also provided by USACE (Steffen, Stringer, Daylor, Neumann, & Zagona, 2015). USACE SWT and CADSWES staff also provided aid in understanding the RWM and how to apply its objects and methods to this study.




Figure 3. RiverWare Model Domain

### **3. Flood Routing Model**

The FERC SPD recommended GRDA demonstrate it has validated its model results against the RWM output. Mead & Hunt developed the FRM to replicate, as closely as possible, the Project flow routing decisions in the RWM as an input to the OM. The FRM includes (from upstream to downstream) Pensacola Dam, Kerr Dam, and Fort Gibson Dam because these operate as a subsystem for reservoir level balancing. The FRM is needed to investigate hypothetical events and operating scenarios that would be difficult and time-consuming to program into the RWM.

#### **3.1 Input Data**

Input data for the FRM includes river discharge upstream of Pensacola Dam, local inflows to each reservoir, evaporation and seepage rates, reservoir stage-storage-area tables, reservoir operating level tables, maximum regulated spill tables, induced surcharge tables, seasonal Project target reservoir elevation table, and hydrologic routing coefficient tables from the RWM.

#### **3.2 Methodology**

The FRM was developed using Visual Basic for Applications (VBA) code within an Excel spreadsheet. The VBA code loops through the time series calculations to solve the model. The VBA code computes formulas to calculate the system state and flow routing decisions for each daily time step, then copies the formulas to the next daily time step and stores the results as plain text in the Excel spreadsheet. In this way, the file size is reduced, and the computation speed improved. The VBA code also dynamically updates a table that relates the operating balance level at Pensacola to the seasonal target elevation and corresponding flood pool elevations and volumes based on the current solution day.

Minimum surcharge and maximum regulated outflows are calculated individually for each dam from upstream to downstream. Operating levels are balanced upstream to downstream and highest to lowest, within calculated outflow limits. Individual dam and Lower Grand (Neosho) subsystem limits are checked. Conservation pool rules and hydropower rules are ignored for purposes of flow routing. Modeled objects include reservoirs, control points, and reaches.

Methods from the RWM replicated in the FRM include:

- Flow combined at nodes and routed downstream hydrologically.
- Evaporation calculated using historical evaporation rates considering modeled reservoir area.
- Constant seepage assumed: 10 cubic feet per second (cfs) at Kerr Dam and 20 cfs at Fort Gibson Dam.
- Minimum surcharge and maximum regulated outflow calculated using the USACE SWT flat top surcharge method.
- Allowable rising release change and allowable falling release change limit how quickly the controlled releases are increased or decreased, subject to other limitations such as minimum surcharge.
- Operating level balancing seeks to maintain similar balance levels in each reservoir.
- Regulating discharges of 100,000 cfs established in the water control manual are considered for Pensacola Dam, Kerr Dam, and Fort Gibson Dam (USACE, 1980).

## 4. Operations Model

Mead & Hunt developed an OM to simulate flow routing, hydropower scheduling, and other Project constraints on an hourly time step. Because electricity prices vary widely within a day, hourly time steps provide improved accuracy for hydropower operations simulation. The OM was developed using VBA code within an Excel spreadsheet, as described in more detail below.

### 4.1 Input Data and Preparation

Mead & Hunt obtained data for the OM from GRDA and USACE. Input data includes project drawings, rating curves, time series data, and information from the RWM. Most of the time series data was available in hourly or sub-hourly time steps from April 1, 2004 through December 31, 2019 (the end date in the RWM), so this period was selected for analysis. Descriptions and sources of each input data set are described below, along with descriptions of the methods used to prepare the data for input to the OM. **Appendix B** contains a collection of the information described in this section.

#### 4.1.1 Headloss vs. Turbine Discharge

GRDA sent Mead & Hunt drawings of the Pensacola and Kerr hydroelectric facilities showing the dimensions of the water passages from the intake to the tailrace at each powerhouse (GRDA, 1961), (GRDA, 1987). The dimensions shown on these drawings were used to estimate the hydraulic friction and form losses as part of the turbine net head calculation.

Facility drawings for the Pensacola and Kerr facilities were used to identify specific friction loss (i.e., conduit roughness) and minor loss (e.g., bends, contractions, or entrance and exit losses) components between the reservoirs and the turbines. It is common practice for turbine manufacturers to include the hydraulic losses from the scroll case entrance through the tailrace in the turbine hill curve efficiencies, so these losses were specifically excluded from the headloss calculations.

Total headloss was calculated using a combination of the Darcy-Weisbach formula for friction losses and assumed minor loss coefficients. To simplify spreadsheet calculations, major and minor losses are expressed in terms of a flow-based headloss coefficient, Kq, according to the equations below:

$$H_L = Kq * Q^2$$

$$Kq = \frac{0.025 * f * L}{D_h^5}$$

$$Kq = \frac{Kv}{2gA^2}$$

where:

H<sub>L</sub> = headloss (ft)

Kq = flow-based headloss coefficient

Kv = velocity-based headloss coefficient

$Q$  = turbine discharge ( $\text{ft}^3/\text{s}$ )

$L$  = pipe length (ft)

$f$  = Darcy-Weisbach resistance coefficient

$D_h$  = Hydraulic diameter (ft)

$A$  = pipe wetted area ( $\text{ft}^2$ )

$g$  = gravity constant ( $32.146 \text{ ft/s}^2$ )

The resistance coefficient varies with pipe size, pipe roughness, fluid kinematic viscosity, and discharge. Resistance coefficients were determined based on the following equations, which approximate the curves of the Moody Diagram.

Von Karman-Prandtl equation for smooth pipe flow:

$$\frac{1}{\sqrt{f}} = 2 \log_{10}(Re\sqrt{f}) - 0.8$$

$$Re = D_h V \nu$$

where:

$Re$  = Reynold's Number

$V$  = average velocity (ft/s)

$\nu$  = kinematic viscosity of fluid ( $\text{ft}^2/\text{s}$ )

Von Karman-Prandtl equation for rough pipe flow:

$$\frac{1}{\sqrt{f}} = 2 \log_{10} \frac{D_h}{2k} + 1.74$$

where:

$k$  = absolute roughness of pipe wall (ft)

Colebrook-White equation for transition flow:

$$\frac{1}{\sqrt{f}} = -2 \log_{10} \left( \frac{k}{3.7D_h} + \frac{2.51}{Re\sqrt{f}} \right)$$

Friction losses for Pensacola were calculated assuming water at 50° F, roughness of 0.00015 feet (steel), and acceleration due to gravity of 32.146 ft/s<sup>2</sup>. Minor loss coefficients were selected using the appropriate Hydraulic Design Criteria charts (USACE, 1987).

The total calculated flow-based headloss coefficient ( $K_q$ ) for Pensacola was  $4.50 \times 10^{-7}$ , and for Kerr was  $4.11 \times 10^{-9}$ .

#### **4.1.2 Stage-Area-Storage Tables**

For model validation purposes, reservoir stage-area-storage-tables for Pensacola and Kerr from the RWM were used in the OM. As discussed in **Section 5.4.4**, other more recent bathymetric survey data were incorporated post-validation to improve later simulations (Dewberry, 2011), (Hunter, Trevisan, Villa, & Smith, 2020).

#### **4.1.3 Turbine Efficiency**

##### ***Pensacola***

Efficiency curves for the Pensacola generators were transcribed from the Siemens efficiency calculations (Siemens, 1999) in terms of generator efficiency vs. percent rated generator load, assuming rated brake power of 18,112 kilowatt (kW) at 0.90 power factor.

Efficiency vs. turbine discharge vs. net head curves for the Pensacola turbines (air valves closed condition) were transcribed from the Voith hill curve (Voith, 1997). Efficiency curves for the condition when the dissolved oxygen (DO) air valves are fully open were transcribed from the Accusonic Unit 3 preliminary performance test report (Walsh, 1999).

Two efficiency curves were developed for Pensacola: one for normal operation with all the DO air valves closed, and one for derated operation with all the DO air valves fully open (90 degrees open).

The normal operation turbine efficiency vs. turbine discharge vs. net head curve was transcribed from the Voith hill curve into an Excel spreadsheet table. The generator efficiency vs. load curve was then multiplied by the turbine efficiencies to develop a total turbine-generator efficiency vs. discharge vs. net head table.

The derated operation (air valves open) turbine efficiencies at a net head of 117.5 feet were transcribed from the Accusonic report. The ratio of derated turbine efficiency to normal turbine efficiency for a given turbine discharge was assumed to be constant across the entire range of net head values used (95 feet to 140 feet). After extrapolating the derated turbine efficiencies, the generator efficiency vs. load curve was again applied to develop a total turbine-generator efficiency vs. turbine discharge vs. net head table for derated operation.

##### ***Kerr***

Efficiency curves for the Kerr generators were transcribed from the table in Section 2.3.1 of the Alstom generator calculations (Bertrand, 2009) in terms of generator efficiency vs. percent rated generator load, assuming rated brake power of 33,036 kW at 0.93 power factor.

Power vs. turbine discharge vs. net head curves for the Kerr turbines (pre-refurbishment) were transcribed from the original 1962 prototype unit curves (EEC, 1962a). Relative turbine efficiencies for the Kerr turbines (post-refurbishment) were transcribed from the Alstom index test results (Alstom, 2010).

The efficiency curves for Kerr were developed based on the original 1962 prototype efficiency curve and the 2010 post-refurbishment index testing. The total turbine-generator efficiency vs.

turbine discharge vs. net head table for the original units was developed using a similar methodology as for Pensacola. Alstom reported index test results as a relative turbine efficiency (refurbished units relative to the original 1962 prototype units) vs. refurbished turbine power at a net head of 56 feet. Index efficiencies were applied across the entire domain of the original hill curve by multiplying the relative efficiency at an equivalent discharge by the maximum original turbine efficiency value at each net head.

#### **4.1.4 Turbine Maximum Discharge**

The maximum allowable turbine discharge (to avoid cavitation) vs. net head limit for Pensacola was determined from the entrance edge cavitation lines on the Voith hill curve (Voith, 1997). The maximum turbine discharge vs. net head limit for Kerr was determined from the limit of Kaplan operation line on the original 1962 prototype unit curves (EEC, 1962b).

#### **4.1.5 Tailwater Rating Curves**

The tailwater (TW) elevation vs. total discharge rating curve for Pensacola Dam was developed based on the historical observed TW elevation and discharge paired data provided by GRDA. The elevation-discharge data pairs were plotted, and a table of paired values was developed based on a best fit through the observed points.

The TW elevation vs. total discharge rating curve for Kerr Dam was developed using USGS gage data: Neosho River near Langley, OK (USGS Gage No. 07190500). The gage data pairs were plotted, and a table of paired values was developed based on a best fit through the gage data points.

#### **4.1.6 Unit Outages**

Individual turbine unit outages are recorded in terms of the start and end date/time of each outage. The outages can be either scheduled or unscheduled, and the type of outage can be forced, planned, maintenance, or de-rated generation output (e.g., DO air valve operation at Pensacola).

Records of the date and time for the beginning and ending of outages for individual turbine-generator units were used to construct time series of unit outages. Overlapping outages were reconciled when the beginning or ending timestamp of a listed outage fell within the timeframe of another outage for the same unit. An hourly time series was constructed to indicate the status of each individual unit (online or offline) for each time step. Lastly, the total number of units online for each time step at each facility was determined. This data was used by the OM to determine the total turbine discharge capacity available for a given time step.

#### **4.1.7 Dissolved Oxygen Air Valves**

Dissolved Oxygen data, including measured DO levels and the status of each of the six Pensacola DO air valves, was available between January 1, 2004 and April 13, 2006 (non-contiguous data). Oklahoma Water Resources Board Title 785.45-5-12 describes seasonal DO concentrations needed to support various subcategories of Fish and Wildlife beneficial use designations for streams (OAC, 2013). The prescribed seasonal DO concentrations were considered along with records of measured DO concentrations and individual air valve status

from Pensacola to estimate when the air valves may have typically been opened during the modeled period of analysis, as described below. The model accounts for the status of the air valves by switching between two different turbine efficiency curves to represent the decrease in turbine efficiency when the air valves are open.

For Pensacola, the prescribed seasonal DO concentrations were considered along with records of DO levels; individual air valve status; actual generation output; and head, efficiency, and flow data to estimate when the air valves may have typically been opened during the modeled period of analysis. There are no DO air valves at Kerr.

#### **4.1.8 Electricity Prices**

Hourly day-ahead and real-time locational marginal prices (in terms of dollars per megawatt-hour [MWh]) for electrical energy produced at Pensacola and Kerr were available from March 1, 2014 to December 31, 2020.

Daily natural gas settlement prices for the Henry Hub trading point were available from March 1, 2004 through December 31, 2020. Natural gas prices were used to index the electricity prices across the full range of analysis dates.

Hourly electricity prices for both day-ahead and real-time markets over the period between March 1, 2014 and December 31, 2020 were divided by the corresponding daily natural gas price to determine the hourly heat rate pattern for this period. This heat rate pattern was then applied to corresponding dates when no hourly electricity prices were available (prior to March 1, 2014). The assumed hourly heat rate was then multiplied by the actual daily historical natural gas settlement prices going back to April 1, 2004 to estimate the historical electricity prices for the period when actual hourly data was not available.

#### **4.1.9 Spillway Capacity**

USACE spillway discharge capacity ratings were reviewed for Pensacola and Kerr, but for the purposes of model validation the rating tables from the RWM will be used instead (USACE, 1990), (USACE, 1991).

## **4.2 Methodology**

The objective function of the OM is to maximize the hydropower generation revenue at each facility while simultaneously satisfying various physical and operational constraints (e.g., reservoir level management, flow routing from the FRM, scheduling of power sales, and operation of the turbines within their allowable range). Many dependent functions comprise the overall objective function and are summarized here:

- Total discharge computed by the FRM is also used by the OM when the reservoir transitions into flood operations, which occurs when the pool is more than 0.5 feet from the target elevation. Otherwise, for normal operations, discharge is determined based on optimal hydropower generation scheduling.
- Modeled revenue is a function of scheduled power and electricity price (both day-ahead and real-time).
- Power is a function of turbine discharge, net head, and total turbine-generator efficiency.

- Net head is a function of headwater, tailwater, and headloss.
- Efficiency is a function of turbine discharge, net head, and DO air valve open/closed status (Pensacola only).
- Turbine discharge is a function of best efficiency point discharge, maximum allowable discharge (avoiding possible cavitation), current reservoir storage volume, forecast inflow volume, electricity price, production cost, the number of units online.
- Reservoir storage volume is a function of inflow, turbine discharge, spillway discharge, evaporation, and seepage (Kerr only, no seepage at Pensacola in RWM).
- Other parameter dependencies have been discussed in the description of the input data preparation in **Section 4.1**.

The OM is driven by VBA code to do two things: 1) solve an iterative loop for the net head values, and 2) step through the time series one day at a time. The Excel spreadsheets contain formulas to optimize the hydroelectric operations for a 24-hour period. The VBA code copies the formulas down from one day to the next as each 24-hour period is solved, preserving the solution values. In this way, the Excel spreadsheets are kept to a manageable size and overall calculation speed is improved.

At the beginning of the solution for a given 24-hour period, an estimated value for net head at each hourly time step is assumed (final values from one day are copied down to the next day to provide the first estimated value). The net head is used to calculate various parameters related to the turbine and spillway discharge, which in turn are used to calculate the TW elevation and headloss, which are then used to calculate the next estimated value for net head.

Each scenario model is solved first for Pensacola. The resulting total discharge (turbines plus spillway) from Pensacola is then hydrologically routed downstream to Kerr Dam in a manner consistent with the RWM hydrologic routing. The routed Pensacola Dam discharge for the given scenario, plus tributary inflows to Lake Hudson, are then combined and copied as inflow to the OM for Kerr.

Hourly time series data produced in the OM includes reservoir elevation, turbine discharge, spillway discharge, net head, power (scheduled day-ahead, real-time buy-back, real-time scheduled, and total), and revenue (day-ahead sales, buy-back cost, real-time sales, and total).

## 5. Validation

Model variables used to validate performance of the OM and FRM against the RWM output included total discharge from a reservoir and elevation of a reservoir. Reservoir storage and balance level were also available as validation parameters but were simple corollaries for elevation. Because elevation is a more intuitive parameter for understanding the system state, it was used rather than the other corresponding parameters.

The date range for OM validation was April 1, 2004 to December 31, 2019. This was the overlapping date range for which data were available from the RWM and when hourly data were available for the OM. The FRM was validated against the RWM using results as far back as 1940.

Performance metrics included the Coefficient of Determination ( $R^2$ ) and the Nash-Sutcliffe Efficiency (NSE).  $R^2$  is an index of the degree of linear relationship between source and simulated data.  $R^2$  represents correlation between models and dispersion of data relative to that correlation. It does not evaluate accuracy, only correlation. NSE is an index of how well the source versus simulated data fits a perfect 1:1 correlation slope line. Plotting on a 1:1 line indicates consistent prediction at lower and higher values. However, NSE is more sensitive to extreme values. Formulas for  $R^2$  and NSE are available in literature and given below for reference. The optimal value for both metrics is 1. For  $R^2$ , the optimal trendline intercept is 0,0 and the optimal trendline slope is 1. **Table 1** lists qualitative ranges for evaluating model validation using these metrics (Moriasi, Gitau, Pai, & Daggupati, 2015).

$$R^2 = \left[ \frac{\sum_{i=1}^n (O_i - \bar{O})(P_i - \bar{P})}{\sqrt{\sum_{i=1}^n (O_i - \bar{O})^2} \sqrt{\sum_{i=1}^n (P_i - \bar{P})^2}} \right]^2$$
$$\text{NSE} = 1 - \frac{\sum_{i=1}^n (O_i - P_i)^2}{\sum_{i=1}^n (O_i - \bar{O})^2}$$


Table 1. Summary of Performance Metrics

Metric	Range	Not Satisfactory	Satisfactory	Good	Very Good
$R^2$	0 to 1	$\leq 0.60$	0.60 to $\leq 0.75$	0.75 to $\leq 0.85$	$> 0.85$
NSE	$-\infty$ to 1	$\leq 0.50$	0.50 to $\leq 0.70$	0.70 to $\leq 0.80$	$> 0.80$

Validation of the OM against the RWM output was performed using similar inputs as the RWM for historical discharge, evaporation, seepage, stage-storage-area tables, reservoir operating level tables, maximum regulated spill tables, induced surcharge tables, the seasonal Project target reservoir elevation table, and hydrologic routing coefficient tables. Following validation, some of these inputs were updated and expanded to meet the needs of the study, as discussed in **Section 5.4**.

### 5.1 Validation Results: Flood Routing Model

The first step in model validation was comparison of the FRM to the RWM results. The FRM was validated against the RWM results for the entire RWM period of record, which is Jan 1, 1940 through December 31, 2019 as shown in **Figure 4** below.



*Figure 4. Flood Routing Model Validation Period of Record*

The FRM simulates many of the rules and constraints in the RWM, with a notable exception: the FRM cannot account for operating level balancing due to the flow restriction at Van Buren, because it is outside the study area. The allowable maximum discharge at Van Buren is a function of the time of year and the amount of basin storage currently utilized at upstream reservoirs, as shown in **Figure 5<sup>1</sup>**.

<sup>1</sup> Copy of Plate 7-58 from (USACE, 1980).




Figure 5. Van Buren Guide Curve

The RWM will sometimes hold the pool higher for extended periods at both Pensacola and Kerr to help manage the discharge at Van Buren. This can result in what appears to be underprediction of peak stages by the FRM on the correlation plots but is more often an underprediction of the duration of those peak stages, as illustrated in **Figure 6** below for the July 2007 event. The modeled peak stages were similar between the FRM and RWM for this event, but the FRM returned the pool to the normal elevation sooner than the RWM. The Van Buren Percent Full Regulation Parameter exceeded 90% for this event, resulting in significant outflow restrictions at upstream dams in the RWM, including at Pensacola and Kerr. Those restrictions were not present in the three-reservoir FRM, and therefore the pool was returned to the normal level soon after the peak inflows subsided. This resulted in a difference between the RWM and FRM stages up to about nine feet for several days, which had the effect of decreasing the correlation metrics.




Figure 6. Modeled July 2007 Pensacola Elevations

Another feature of the RWM which decreases the correlation of the models is time step oscillation. As the model shifts between different operating rules at threshold pool levels (i.e., top of conservation pool), and as the total system state changes over time, the decision-making of the model can result in fluctuations from one daily time step to the next. For example, an increased discharge at one time step can increase the downstream reservoir level, resulting in an increased operating balance level and forcing a lower discharge at the next time step, and so on. **Figure 7** illustrates this effect as it occurs in both the RWM and FRM.




Figure 7. RiverWare vs. Flood Routing Model Oscillation Comparison

Time step oscillation can decrease the apparent correlation between the models, especially when the oscillation happens to begin at different time steps between the two models, so that one model is decreasing while the other is increasing. In order to obtain a clearer comparison between two models, the effect of time step oscillation must first be removed by time-averaging across two daily model time steps. This was done for both models before computing the correlation, and effectively mitigated the problem of oscillation on the model timestep-scale.

**Figure 8** and **Figure 9** show the RWM vs. FRM validation plots for Pensacola and Kerr, respectively. The validation metrics are summarized in **Table 2** below.




Figure 8. RiverWare Model vs. Flood Routing Model Correlation Plots at Pensacola




Figure 9. RiverWare Model vs. Flood Routing Model Correlation Plots at Kerr

Table 2. RiverWare Model vs. Flood Routing Model Validation Results

	Pensacola		Kerr		
	Discharge	Elevation	Discharge	Elevation	
	NSE	0.89 (Very Good)	0.81 (Very Good)	0.87 (Very Good)	0.68 (Satisfactory)
	R <sup>2</sup>	0.90 (Very Good)	0.81 (Good)	0.88 (Very Good)	0.752 (Good)

## 5.2 Validation Results: Operations Model

The OM was validated against the RWM results for the period for which hourly data was available for the OM, which is April 1, 2004 through December 31, 2019 as shown in **Figure 10** below.




Figure 10. Operations Model Validation Period of Record

The OM builds on the flow routing decisions from the FRM by superimposing hydropower optimization logic onto the total discharge prescribed by the FRM. In order to link the OM to the FRM, a transition must take place between normal low-flow operations, when the hydropower optimization takes precedence, and higher-flow events, when the FRM-predicted releases take precedence. At the time of model validation, this transition was assumed to occur when the current elevation in the OM deviated more than 0.5 feet from the target elevation. When this occurred, the OM attempted to match the total discharge prescribed by the FRM until the pool again returned to within 0.5 feet of the target elevation. This was a simplified approach to linking the models for validation purposes and has since been improved, as discussed in **Section 5.4.3**. Because of this additional degree of separation, the validation results were slightly lower for the RWM vs. OM comparison, shown in **Figure 11** and **Figure 12** and summarized in **Table 3**.




Figure 11. RiverWare Model vs. Operations Model Correlation Plots at Pensacola




Figure 12. RiverWare Model vs. Operations Model Correlation Plots at Kerr

Table 3. RiverWare Model vs. Operations Model Validation Results

	Pensacola		Kerr	
	Discharge	Elevation	Discharge	Elevation
NSE	0.87 (Very Good)	0.80 (Very Good)	0.87 (Very Good)	0.61 (Satisfactory)
R <sup>2</sup>	0.86 (Very Good)	0.81 (Good)	0.86 (Very Good)	0.69 (Satisfactory)

Despite the aforementioned limitations of the RWM, which has been replicated in the FRM with only three reservoirs while incorporating detailed hourly hydropower optimization calculations in the OM, the validation metrics are in the range of satisfactory to very good. Therefore, the models have been

validated against the RWM results and the study has since proceeded to improve the model inputs and logic beyond the limitations of the RWM, as discussed in **Section 5.4** below.

### 5.3 Validation Against USGS Gage Data

In its February 22, 2022 determination, FERC recommended that GRDA compare water surface elevations observed at the USGS gage on the upstream side of the dam to the simulated HEC-RAS stage hydrographs for the December 2015 and October 2009 inflow events and provide a graphical comparison of the simulated and observed water surface elevations over a daily time step for the duration of each flood event. GRDA included the FERC-requested comparison in this OM report because the HEC-RAS stage hydrographs at the dam are calculated by the OM.

Because the RWM and FRM do not reflect actual real-time decisions during past inflow events, but rather initial planning-level flow routing decisions, GRDA used the historical records of spillway gate openings to simulate operations for these two historical validation simulations. The reservoir inflow hydrographs for the December 2015 and October 2009 inflow events were back-calculated using GRDA's records of Project discharge and reservoir elevation and the stage-storage table from the 2019 USGS bathymetry survey. The USACE discharge rating for the spillway gates was used to calculate the spillway discharge for each time step based on the gate openings and the OM-simulated reservoir level. The OM made hydropower generation decisions as for the other simulations, but the spillway discharge was calculated using the historical spillway gate openings, which were set in response to USACE directives when the reservoir level was above, or expected to go above, Elevation 745 feet PD. The OM reservoir level simulated showed very good agreement with the observed USGS gage No. 07190000 data, as shown in **Figure 13** and **Figure 14**.




Figure 13. Validation Against USGS Gage Data, October 2009




Figure 14. Validation Against USGS Gage Data, December 2015

## 5.4 Post-Validation Model Improvements

Following model validation, improvements were made to address known issues, as discussed below.

### 5.4.1 Flood Routing Model Ramping Rate Restrictions

In addition to the period-of-record model used to validate the FRM against the RWM results, various single-event simulations were previously computed to provide inputs to the CHM, as discussed below. One of those single-event simulations included a synthetic 100-year event, the development of which is documented in the USR report. It was noted that for the 100-year event simulation, the FRM caused the pool at Pensacola to drop below the target elevation on the falling limb of the hydrograph. This occurred because the RWM allowable falling release change (AFRC) of 99,174 AF/day disrupted the flow routing logic and resulted in too much discharge as the pool approached the target elevation. The AFRC does not typically interfere in this way for Pensacola, but the steeply falling discharge hydrograph of the hypothetical 100-year event simulation caused it to behave differently than for historical events. This issue was observed to affect the results for Kerr in some historical events, in addition to the 100-year event simulation.

This issue was corrected by adding logical checks to ensure that the target elevation would take precedence over the AFRC criterion.

### 5.4.2 Operations Model Turbine Shutoff Compensation

When power prices on the day-ahead market were positive, the OM scheduled the turbines to generate. If this occurred during a high-flow event, the OM subtracted the scheduled turbine discharge from the total discharge prescribed by the FRM when calculating the spillway discharge needed for that day. The spillway discharge was assumed to be constant for each day. If the power prices on the real-time market dropped below the production cost or went negative, the OM would buy back the scheduled generation, which resulted in total discharge less than the

average prescribed by the FRM for that day. This resulted in pool levels increasing above those predicted by the FRM in some cases.

This issue was corrected by allowing the spillway discharge to adjust on an hourly time step to compensate when the turbines shut down due to unprofitable market conditions.

#### **5.4.3 Flood Routing Model Stage Matching**

Total discharge computed by the FRM was also used by the OM when the reservoir transitioned into flood operations, which was assumed to occur when the current elevation in the OM drifted more than 0.5 feet from the target elevation. When this occurred, the OM attempted to match the total discharge prescribed by the FRM until the pool again returned to within 0.5 feet of the target elevation. Different initial conditions, such as alternative assumed starting elevations, in some cases resulted in inconsistencies in reservoir elevation for two simulations of the same event which continued throughout the peak of the event.

This issue was corrected by adding criteria for the OM to gradually bring the reservoir elevation back in line with the FRM results when the pool is in flood stage. Because most of the rules and constraints in the RWM relate to discharge, not stage (e.g., AFRC, spillway minimum surcharge, spillway maximum regulated discharge, downstream channel regulating discharges), the OM was originally set up to match discharge and not stage. The methodology used to constrain the OM to the FRM using both discharge and stage strikes a balance between attempting to match peak stages and keeping as closely aligned as possible to the discharge-related limitations in the RWM.

The criteria used to implement this solution included a two-step adjustment:

1. First, the model used the projected midnight reservoir level in the case of no spill to compute a ratio (FRM discharge vs. elevation ratio) to bring the OM back in line with the FRM discharge and/or elevation results based on a sliding scale:
  - a. If the projected midnight reservoir level with no spill was below the midnight target elevation, then the FRM total discharge result was maintained (FRM discharge vs. elevation ratio = 1).
  - b. If the projected midnight reservoir level with no spill was between the midnight target elevation and the top of flood pool (Elevation 755), then a ratio was assigned based on linearly interpolated storage values corresponding to those elevations ( $1 > \text{FRM discharge vs. elevation ratio} > 0$ ).
  - c. If the projected midnight reservoir level with no spill was at or above the top of flood pool (Elevation 755), then the FRM elevation result was maintained (FRM discharge vs. elevation ratio = 0).
2. Second, the magnitude of the adjustment used to match the FRM total discharge result was also computed as a ratio (FRM discharge multiplier) between 0 and 1 based on the difference in elevation between the projected midnight reservoir level in the case of no spill and the midnight target elevation:
  - a. For differences less than 0.25 feet, no adjustment was made to spill discharge based on the FRM total discharge result (FRM discharge multiplier = 0).

- b. For differences between 0.25 and 0.5 feet, the ratio was linearly interpolated by elevation between 0 and 0.75 ( $0 < \text{FRM discharge multiplier} < 0.75$ ).
- c. For differences between 0.5 and 0.75 feet, the ratio was linearly interpolated by elevation between 0.75 and 1 ( $0.75 < \text{FRM discharge multiplier} < 1$ ).
- d. For differences of 0.75 feet or more, the entire adjustment for matching FRM total discharge was used ( $\text{FRM discharge multiplier} = 1$ ), but the OM spill discharge could still be adjusted down based on the FRM discharge vs. elevation ratio discussed above.

The final calculation to determine the spillway discharge at each time step was:

$$Q = a * Qq + (1-a) * (b * Qe)$$

where:  $Q$  = spillway discharge for OM time step (cfs)

$Qq$  = OM spillway discharge needed to match total discharge of FRM (cfs)

$Qe$  = OM spillway discharge needed to match midnight elevation of FRM (cfs)

$a$  = FRM discharge vs. elevation ratio ( $0 < a < 1$ )

$b$  = FRM discharge multiplier ( $0 < b < 1$ )

This approach allows the OM to optimize operations freely when the reservoir is within the conservation pool, and gradually shift to matching the FRM results as the reservoir begins to climb into the flood pool.

The cumulative result of the model improvements described above is more consistent in matching OM results to the FRM results during large events.

#### 5.4.4 Updated Stage-Area-Storage Table

The Grand Lake stage-area-storage table used for the FRM and OM was updated following validation to use the data developed by USGS in 2019 and 2020 (Hunter, Trevisan, Villa, & Smith, 2020). The USGS data was interpolated at half-foot intervals and linearly extrapolated to Elevation 780. In response to stakeholder comments following the ISR, GRDA performed a sensitivity analysis of the OM to evaluate the impacts of the updated stage-area-storage table on computed reservoir level.

The OM results using the 2019 bathymetry data were very similar to the OM results using the RWM stage-area-storage table. **Table 4** compares reservoir level metrics for the hourly POR and for individual flow events that occurred within the POR. Differences are small and within the range of model oscillation typical for the RWM and FRM. The RWM and FRM make flow routing decisions based on key elevations, not fixed values of storage, so it is unsurprising that the results were similar after updating the stage-area-storage table. Therefore, the updated stage-area-storage table was used in the study.

*Table 4. Sensitivity Analysis Results for Stage-Area-Storage Update*

Sensitivity Parameter	RWM Stage- Storage Table	2019 Stage- Storage Table	Difference (feet)
POR Average (Mean) Grand Lake Elevation (feet PD)	742.87	742.86	0.01
POR Median Grand Lake Elevation (feet PD)	742.05	742.04	0.01
POR Minimum Grand Lake Elevation (feet PD)	740.87	740.88	0.01
POR Maximum Grand Lake Elevation (feet PD)	754.82	754.82	0.00
Peak Grand Lake Elevation (feet PD), June 2004 (1 year)	744.87	744.83	0.04
Peak Grand Lake Elevation (feet PD), July 2007 (4 year)	754.74	754.73	0.01
Peak Grand Lake Elevation (feet PD), Oct 2009 (3 year)	750.21	750.04	0.17
Peak Grand Lake Elevation (feet PD), Dec 2015 (15 year)	754.82	754.82	0.00

## 6. Scenarios Computed for H&H and Sedimentation Studies

The OM provides stage and discharge hydrograph inputs to other components of the hydrologic and hydraulic modeling study (H&H study), as well as other relicensing studies. For the upstream hydraulic model (UHM) and STM, only the stage hydrographs at Pensacola Dam are needed because the inflow hydrographs at the upstream boundary come from other sources. For the downstream hydraulic model, the stage hydrographs at Kerr Dam, lateral inflow hydrographs to Lake Hudson, and discharge hydrographs at Pensacola Dam are needed.

### 6.1 Single Events for CHM, Baseline Operations

The OM was used to provide CHM inputs for various single-event simulations, consisting of different combinations of historical or hypothetical flow events and initial reservoir elevations within GRDA's anticipated operating range or extreme, hypothetical range, summarized in **Table 5**. These simulations were computed using the baseline operating rules as represented in the RWM, which reflects the seasonal midnight rule curve that was in place prior to license amendment in 2015. For consistency throughout the model development and validation process, these baseline (pre-2015) operating rules were used to reflect what was in the RWM information provided by USACE SWT, which was the baseline for model validation as recommended in the FERC SPD. This is referred to as baseline operations.

Table 5. Single Events for CHM, Baseline Operations

Pensacola Initial Elevation (feet PD)		Sep 1993 (21 year)	Jun 2004 (1 year)	Jul 2007 (4 year)	Oct 2009 (3 year)	Dec 2015 (15 year)	100-year
Extreme, Hypothetical Range	757.0	✓	✓	✓	✓	✓	✓
	753.0	✓	✓	✓	✓	✓	✓
	749.0	✓	✓	✓	✓	✓	✓
Anticipated Range	745.0	✓	✓	✓	✓	✓	✓
	744.5	✓	✓	✓	✓	✓	✓
	744.0	✓	✓	✓	✓	✓	✓
	743.5	✓	✓	✓	✓	✓	✓
	743.0	✓	✓	✓	✓	✓	✓
	742.5	✓	✓	✓	✓	✓	✓
	742.0	✓	✓	✓	✓	✓	✓
Extreme, Hypothetical Range	734.0	✓	✓	✓	✓	✓	✓
Historical (Varies)		✓	✓	✓	✓	✓	N/A
POR Simulation, 746.46				✓*			

\*Corresponds to **Table 6**, see description below.

## 6.2 Single Events for CHM, Anticipated Operations


As proposed in Section 2.6.5 of the H&H Study RSP, “an additional suite of model runs following the same parameters” was run for the operational scenario anticipated by GRDA. As discussed in Section 1.6.2 of GRDA’s December 29, 2021 filing with FERC, GRDA anticipates the following operational parameters will apply during the new license term:

1. GRDA will no longer utilize a rule curve with seasonal target elevations.
2. GRDA will maintain the conservation pool between elevations 742 and 745 feet PD for purposes of normal hydropower operations. While hydropower operations may occur when water surface elevations are outside this range (e.g., maintenance drawdowns and high-flow events), GRDA expects to generally maintain water surface elevations between 742 and 745 feet PD during normal project operations.
3. Instead of managing the project to target a specified seasonal elevation, GRDA’s anticipated operations may fluctuate reservoir levels within the elevational range of 742 and 745 feet PD, for purposes of responding to grid demands, market conditions, and the public interest, such as environmental and recreational considerations.
4. GRDA will continue to adhere to USACE’s direction on flood control operations in accordance with the Water Control Manual.

This operational scenario is referred to as “anticipated operations.” The modeling approach used to demonstrate the potential value of the anticipated operations for hydropower production relies on a statistical comparison of the electricity prices for the current day/hour versus the previous 24-hour or 2-day price patterns. For power scheduled on the day-ahead market, each hourly price for the current calculation day is compared to all the hourly prices within the current and previous calculation days (2-day pattern). The average (mean) and standard deviation is calculated from the 48 hourly values. The number

of standard deviations above or below the 2-day mean is calculated for each hour in the current calculation day. These values are then compared to an incentive table which relates the reservoir level (based on forecast reservoir volume at midnight) to a threshold value (in terms of standard deviations of price) above which generation may be scheduled, subject to other constraints as described in **Section 4 Operations Model**. The incentive table is shaped somewhat like an S-curve so that power scheduling can transition gradually to be more conservative as the pool drops closer to Elevation 742 PD or less conservative (more generation scheduled) as the pool rises closer to Elevation 745 PD. Above and below Elevations 745 and 742 PD, respectively, there is a sharp decrease or increase, respectively, in the standard deviation threshold values so that power generation is always scheduled (subject to other constraints) or never scheduled, respectively, outside of this range.

For power sold on the real-time market, the approach is similar except a moving 24-hour price pattern window is used, comparing the current hourly price to the previous 24 hours. The relationship between elevation and minimum generation price (in standard deviations) is shown in **Figure 15**.



*Figure 15. Minimum Threshold Price for Generation (Anticipated Operations)*

Because the reservoir level fluctuates in response to water availability and electricity market conditions, the average (mean) reservoir level below 745 feet PD was used as the guide curve elevation in the FRM. For the hourly period of record from April 1, 2004 through December 31, 2019, this average elevation was 743.1 feet PD.

The OM was used to provide CHM inputs for single-event simulations consisting of the minimum and maximum bounding cases for flow events and initial reservoir elevations in the extreme, hypothetical range. Another event of historical importance to upstream communities (July 2007 [4 year]) was also simulated using the expected initial reservoir elevation based on the OM period-of-record simulation with anticipated operations. These simulations were computed using the anticipated operating rules and are summarized in **Table 6**.

*Table 6. Single Events for CHM, Anticipated Operations*

Pensacola Initial Elevation (feet PD)	Jun 2004 (1 year)	Jul 2007 (4 year)	100-year
Extreme, Hypothetical Range	757.0	✓	✓
POR Simulation	745.9	✓	✓
Extreme, Hypothetical Range	734.0	✓	✓

Differences in WSEL computed for these anticipated operation scenarios have been compared to the corresponding baseline operation scenarios, and that information is presented in the UHM report. One additional baseline operation scenario was added for this purpose: the July 2007 (4 year) event with the expected initial reservoir elevation (746.46 feet PD) based on the OM period-of-record simulation with baseline operations.

### **6.3 50-year Simulations for STM**

The STM was used to predict changes in river and lake bathymetry based on sediment transport processes occurring over the expected license term of 50 years, as discussed in the STM report. The OM was used to provide STM inputs in terms of stage hydrographs at Pensacola Dam for various scenarios related to baseline and anticipated operations, including a sensitivity analysis for higher and lower sedimentation rates.

Another version of the OM was developed to calculate the STM inputs for the 50-year period from January 1, 2020 through December 31, 2069. The hydrologic inputs over this timeframe were randomized from the historical RWM data between January 1, 1970 and December 31, 2019. For the OM-specific inputs, data from the 12-year period from January 1, 2008 through December 31, 2019 was repeated to cover the rest of the 50-year simulation. This applied to electricity price factors, turbine air valve status, and the number of units online.

The OM was modified so that the reservoir stage-area-storage table could be interpolated through time as the average storage volume changed. For the first iteration, the OM was computed for the 50-year simulation using existing stage-area-storage data only, for both baseline and anticipated operations, and the resulting stage hydrographs at Pensacola Dam were passed to the STM. Then the STM was computed for both baseline and anticipated operation scenarios, and the resulting stage-storage tables at the end of the 50-year period were passed back to the OM. Because the simplified 1D geometry of the STM does not predict the reservoir surface area as well as the USGS survey data, the 2019 table for Grand Lake was modified to calculate future area based on the proportional changes in storage at a given elevation as computed by the STM. For the second iteration, the OM interpolated between the existing and future stage-area-storage tables using linear interpolation for each day in the 50-year simulation. The OM stage results were again passed to the STM, and the STM re-computed. The stage-area-storage tables resulting from this second iteration were compared to the first to confirm that no further iteration was needed. The future stage-area-storage tables thus computed could then be used to examine the effect of sedimentation over the license term on upstream water levels using the 1D UHM, as discussed in the following section.

In addition to the STM scenarios computed using the expected parameters for sedimentation, two sensitivity cases were computed using lower and higher rates of sedimentation. The 50-year OM scenarios computed in support of the STM are summarized in **Table 7**.

*Table 7. 50-year Simulations for STM*

Operations	Lower Sediment Rate	Expected Sediment Rate	Higher Sediment Rate
Baseline		✓	
Anticipated	✓	✓	✓

## 6.4 Single Events for 1D UHM, Anticipated Operations

The OM was used to provide 1D UHM inputs for single-event simulations consisting of three initial reservoir elevations, two inflow events, and five different sedimentation conditions. The 1D UHM is a version of the STM reconfigured to run short-duration events to predict the resulting upstream water surface profiles, as described in the STM report. The simulations included the July 2007 (4 year) and 100-year events and initial reservoir elevations of 740-, 745-, and 750-feet PD as recommended in the May 27, 2022 FERC Determination. Scenarios were computed to compare:

- future vs. existing (2019) bathymetry conditions for anticipated operations,
- expected sedimentation rate vs. lower and higher sensitivity cases, and
- anticipated vs. baseline operations using future bathymetry.

Scenarios computed in support of the 1D UHM are summarized in **Table 8**.

*Table 8. Single Events for 1D UHM*

Stage-Storage Condition	July 2007 (4 year)			100-year		
	740	745	750	740	745	750
Existing, Anticipated Operations	✓	✓	✓	✓	✓	✓
Future, Anticipated Operations, Lower Sediment Rate	✓	✓	✓	✓	✓	✓
Future, Anticipated Operations, Expected Sediment Rate	✓	✓	✓	✓	✓	✓
Future, Anticipated Operations, Higher Sediment Rate	✓	✓	✓	✓	✓	✓
Future, Baseline Operations, Expected Sediment Rate	✓	✓	✓	✓	✓	✓

## 7. Scenarios Computed for Other Studies

The OM was used to calculate statistical changes in water levels and to provide UHM inputs in support of other relicensing studies, including the Aquatic Species Study, Terrestrial Species Study, and Wetlands and Riparian Habitat Study. For each study and certain specific resources within a study, specific seasons were identified as key for determining impacts. The hourly period-of-record OM was truncated slightly to November 1, 2004 through November 1, 2019 so that a whole number of years was used to calculate statistics. The OM was computed for both baseline and anticipated operations using stage-area-storage tables based on the USGS 2019 bathymetry. The specific results computed for each study and resource are discussed below.

## **7.1 Aquatic Species Study**

For the Aquatic Species Study, a comparison between anticipated operations and baseline operations during normal operations and inflows was completed. The Aquatic Species Study team identified the annual seasonal period of May 15 to July 8 as a critical time period surrogate for all lake spawning fish, based upon the nursery period for largemouth bass. For this season, the median reservoir elevation was 744.14 and 744.73 feet PD for baseline and anticipated operations, respectively. The seasonal median inflows on the Neosho River and other Grand Lake tributaries were also calculated from the RWM data for this timeframe. These median reservoir elevations and inflows were then used by the UHM to calculate the upstream water levels and extent of inundation for baseline and anticipated operations.

## **7.2 Terrestrial Species Study**

For the Terrestrial Species Study, the entire calendar year, January 1 through December 31 was recommended by the Terrestrial Species Study Team as the seasonal analysis period because several critical terrestrial species could be most impacted during both their active and inactive or hibernation periods each year. For this season, the median reservoir elevation was 742.04 and 743.10 feet PD for baseline and anticipated operations, respectively. The seasonal median reservoir elevations and inflows were then used by the UHM to calculate the upstream water levels and extent of inundation for baseline and anticipated operations.

Additionally, a seasonal period from April 1 to July 31 was calculated to quantify potential impacts to gray bats. For this season, the percentage of time the reservoir elevation exceeded threshold values of 746, 751, and 752 feet PD were calculated for baseline and anticipated operations.

## **7.3 Wetlands and Riparian Habitat Study**

For the Wetland and Riparian Habitat Study, the annual seasonal period of March 30 to November 2 was recommended by the Wetland and Riparian Habitat Study Team as critical for identifying areas that could change from seasonally flooded to permanently flooded. The critical period corresponds with the growing season as determined from Tulsa, OK climatological records. For this season, the median reservoir elevation was 742.92 and 743.46 feet PD for baseline and anticipated operations, respectively. The seasonal median reservoir elevations and inflows were then used by the UHM to calculate the upstream water levels and extent of inundation for baseline and anticipated operations.

## **7.4 Recreation and Navigation**

Although not part of an official study, an additional case was calculated for the season from June 1 through October 31, which is the peak season for recreation / boating navigation on Grand Lake. For this season, the median reservoir elevation was 743.14 and 743.07 feet PD for baseline and anticipated operations, respectively.

## 8. Summary

On behalf of GRDA, Mead & Hunt developed a three-reservoir version of the RiverWare model, referred to as the FRM, to investigate operating alternatives and hypothetical (non-historical) events. The FRM includes Pensacola, Kerr, and Fort Gibson Dams. Mead & Hunt also developed an OM to simulate hourly hydropower operations at Pensacola and Kerr. GRDA validated its model results against the RWM output, as recommended in the FERC SPD. The OM was also validated by comparing the WSEL results to USGS gage data upstream of Pensacola Dam for two historical events recommended by the FERC. Sensitivity of OM results to stage-area-storage table updates were calculated. The OM was then improved to fix known issues and expanded to include anticipated operations. All FERC-requested modifications have been completed. The OM was used to provide inputs for the CHM, STM, 1D UHM, and other relicensing studies and resource evaluations. This report documents the development of the OM updated results that will be presented at the USR meeting.

## 9. References

- Bertrand, A. (2009). *Electrical and Mechanical Calculations Characteristics of Generators 1, 2, 3, and 4*. Alstom Power & Transport Canada Inc. (Rev. July 7, 2014).
- CADSWES. (2020). *RiverWare Technical Documentation Version 8.1*. University of Colorado Boulder.
- CFR. (1944). *Regulations for use of storage waters*. 33 U.S. Code § 709.
- CFR. (1945). *Pensacola Dam and Reservoir, Grand (Neosho) River, Okla*. 33 CFR § 208.25.
- Dewberry. (2011). *USGS Grand Lake, OK LiDAR Project*. Prepared for the U.S. Geological Survey.
- EEC. (1962a). *Full-Size Turbine Power and Discharge Predicted from Model Tests, Markham Ferry*. The English Electric Company Limited, Hydraulics Research Laboratory, Water Turbine Department, Rugby. Figure 12. March 1962.
- EEC. (1962b). *Variation of Predicted Turbine Output with Tail Water Elevation, Markham Ferry*. The English Electric Company Limited, Hydraulics Research Laboratory, Water Turbine Department, Rugby. Figure 23. October 1962.
- GRDA. (1961). As-Built Drawings. *Dam and Power House, Power House and Intake, Transverse Sections, Markham Ferry Project*.
- GRDA. (1987). Drawings. *Dam and Powerhouse Section and Elevation of Dam and Powerhouse, Pensacola Dam Hydropower Project. Application for FERC License, FERC No. 1494-169, Exhibit F, Sheet 2*.
- Hunter, S. L., Trevisan, A. R., Villa, J., & Smith, K. A. (2020). *Bathymetric Map, Surface Area, and Capacity of Grand Lake O' the Cherokees, Northeastern Oklahoma, 2019*. Denver: USGS.
- Mead & Hunt. (2021). *H&H Modeling: Operations Model Input Status Report*.
- Moriasi, D. N., Gitau, M. W., Pai, N., & Daggupati, P. (2015). Hydrologic and Water Quality Models: Performance Measures and Evaluation Criteria. *Transactions of the American Society of Agricultural and Biological Engineers*, Vol. 58(6): 1763-1785.
- OAC. (2013). *Title 785. Oklahoma Water Resources Board. Chapter 45. Oklahoma's Water Quality Standards*. Oklahoma Administrative Code. OAC 785.45-5-12. July 1, 2013.
- Siemens. (1999). *Efficiency Calculations, Pensacola Power Plant, Unit No. 3*. Siemens Westinghouse Generator Engineering. Page V of V. January 13, 1999.

Steffen, J., Stringer, J., Daylor, J., Neumann, D., & Zagona, E. (2015). TAPER - A Real-Time Decision Support Tool for Balanced Flood Operation of the Arkansas River in Tulsa District. *3rd Joint Federal Interagency Conference on Sedimentation and Hydrologic Modeling*. Reno, Nevada.

USACE. (1980). *Arkansas River Basin Water Control Master Manual*. Tulsa and Little Rock Districts.

USACE. (1987). *Hydraulic Design Criteria*.

USACE. (1990). *Discharge Rating Curves, Main Spillway. Discharge Rating Curves, East Spillway. Pensacola Reservoir*. Dept. of the Army, Tulsa District Corps of Engineers.

USACE. (1991). *Spillway Rating Curves, Partial and Full Gate Openings. Markham Ferry Reservoir*. Department of the Army, Tulsa District.

USACE. (2020). RiverWare Model for the Arkansas Basin Reservoir System.

Voith. (1997). *Expected Prototype Turbine Performance, Pensacola, Speed = 150 rpm, Centerline Elevation = 630 ft*. Voith Hydro Inc. York, PA. Drawing No. 2677-0146. Figure No. 5.1.3. October, 1997.

Walsh, J. (1999). *Pensacola Power Plant Performance Test on Unit 3 (Preliminary)*. Accusonic Technologies. Falmouth, MA. Report FP-27108B. Figure 2. December 15, 1999.

## **Appendix A. USACE RiverWare Data**

---

		USACE SWT RiverWare Period-of-Record Model, Daily Time Series Data																							
Element		PARS	PARS-COMM	PARS-COMM	COMM	COMM-PENS	COMM-PENS	PENS	PENS	PENS	PENS	PENS	PENS	PENS	PENS-HUDS	PENS-HUDS	HUDS	HUDS							
Parameter		FLOW-LOC CUM		INFLOW		OUTFLOW		FLOW-LOC CUM		INFLOW		OUTFLOW		ELEV	STORAGE	FLOOD-STORAGE	FLOW-RES IN	OLEVEL	FLOW-RES OUT	INFLOW		OUTFLOW		ELEV	FLOOD-STORAGE
Units		cfs	cfs	cfs	cfs	cfs	cfs	cfs	cfs	cfs	cfs	cfs	cfs	ft	acre-ft	acre-ft	cfs	-	cfs	cfs	cfs	cfs	ft	acre-ft	
1	01Jan1940	50	50	50	51	51	51	742.00	1392694	16	262	8.00001	238	238	238	619.02	263								
2	02Jan1940	50	50	50	53	53	52	742.00	1392686	8	81	7.07267	69	69	69	619.01	54								
3	03Jan1940	50	50	50	52	52	53	742.00	1392682	4	134	6.08950	120	120	120	619.00	0								
4	04Jan1940	50	50	50	54	54	53	742.00	1392681	3	347	5.84333	331	331	331	619.00	0								
5	05Jan1940	50	50	50	56	56	55	742.00	1392682	4	280	6.17988	264	264	264	619.04	462								
6	06Jan1940	50	50	50	54	54	55	742.00	1392682	4	252	6.19854	235	235	235	619.01	141								
7	07Jan1940	50	50	50	55	55	55	742.00	1392682	4	261	6.03920	245	245	245	619.01	135								
8	08Jan1940	50	50	50	50	50	52	742.00	1392681	3	297	5.64767	282	282	282	619.00	34								
9	09Jan1940	51	51	51	51	51	51	742.00	1392680	2	393	5.57045	377	377	377	619.02	229								
10	10Jan1940	51	51	51	51	51	51	742.00	1392681	3	367	5.63389	351	351	351	619.02	189								
11	11Jan1940	50	50	50	50	50	50	742.00	1392682	4	372	6.08029	356	356	356	619.02	225								
12	12Jan1940	50	50	50	51	51	51	742.00	1392682	4	372	6.03123	356	356	356	619.01	128								
13	13Jan1940	50	50	50	51	51	51	742.00	1392682	4	433	6.08367	417	417	417	619.02	249								
14	14Jan1940	50	50	50	57	57	55	742.00	1392683	5	434	6.32674	418	418	418	619.03	307								
15	15Jan1940	50	50	50	53	53	55	742.00	1392683	5	325	6.31415	308	308	308	619.01	128								
16	16Jan1940	50	50	50	50	50	51	742.00	1392682	4	396	6.01742	381	381	381	619.02	166								
17	17Jan1940	50	50	50	51	51	51	742.00	1392681	3	420	5.97649	405	405	405	619.03	313								
18	18Jan1940	50	50	50	52	52	51	742.00	1392682	4	318	6.33774	302	302	302	619.02	213								
19	19Jan1940	50	50	50	50	50	51	742.00	1392683	5	302	6.57443	286	286	286	619.02	168								
20	20Jan1940	50	50	50	50	50	50	742.00	1392682	4	325	6.26857	309	309	309	619.02	229								
21	21Jan1940	50	50	50	50	50	50	742.00	1392682	4	296	6.24674	280	280	280	619.02	192								
22	22Jan1940	50	50	50	50	50	50	742.00	1392682	4	292	6.34733	275	275	275	619.02	189								
23	23Jan1940	50	50	50	50	50	50	742.00	1392683	5	288	6.51573	271	271	271	619.02	186								
24	24Jan1940	50	50	50	50	50	50	742.00	1392683	5	274	6.49099	257	257	257	619.01	146								
25	25Jan1940	50	50	50	50	50	50	742.00	1392683	5	284	6.57288	268	268	268	619.01	125								
26	26Jan1940	50	50	50	50	50	50	742.00	1392683	5	300	6.62145	284	284	284	619.01	150								
27	27Jan1940	50	50	50	50	50	50	742.00	1392683	5	291	6.47114	275	275	275	619.01	120								
28	28Jan1940	50	50	50	50	50	50	742.00	1392682	4	320	6.17769	305	305	305	619.02	172								
29	29Jan1940	50	50	50	50	50	50	742.00	1392682	4	299	6.01550	283	283	283	619.01	104								
30	30Jan1940	50	50	50	50	50	50	742.00	1392681	3	362	5.91130	347	347	347	619.02	221								
31	31Jan1940	50	50	50	50	50	50	742.00	1392682	4	346	6.09173	330	330	330	619.02	221								
32	01Feb1940	50	50	50	50	50	50	742.00	1392682	4	424	6.18151	458	458	458	619.04	470								
33	02Feb1940	50	50	50	51	51	50	742.00	1392683	5	393	6.47594	426	426	426	619.04	457								
34	03Feb1940	50	50	50	52	52	52	742.00	1392683	5	399	6.58737	433	433	433	619.05	510								
35	04Feb1940	50	50	50</td																					

		USACE SWT RiverWare Period-of-Record Model, Daily Time Series Data																	
Element	HUDS	HUDS	HUDS	HUDS-FGIB	HUDS-FGIB	FGIB	FGIB	FGIB	FGIB	FT GIBSON-MUSKOGEE	FT GIBSON-MUSKOGEE	PENS	HUDS	FGIB	Van Buren				
Parameter	FLOW-RES IN	OLEVEL	OUTFLOW	INFLOW	OUTFLOW	ELEV	FLOOD-STORAGE	FLOW-RES IN	FLOW-RES OUT	OP-LEVEL	INFLOW	OUTFLOW	EVAP	EVAP	EVAP	Percent Full Regulation Parameter			
Units	cfs	-	cfs	cfs	cfs	ft	acre-ft	cfs	cfs	-	cfs	cfs	in/day	in/day	in/day	-			
1	01Jan1940	238	8.01077	91	91	554.00	67	91	0	8.00075	0	0	0.0094	0.0087	0.0232	0.000			
2	02Jan1940	69	8.00222	160	160	553.98	0	160	368	4.90163	368	276	0.0094	0.0087	0.0232	0.000			
3	03Jan1940	145	5.41351	158	158	553.98	0	158	91	4.90570	91	161	0.0094	0.0087	0.0232	0.000			
4	04Jan1940	365	5.21055	351	351	554.01	140	351	0	8.00157	0	23	0.0094	0.0087	0.0232	0.000			
5	05Jan1940	264	8.01894	17	17	554.00	60	17	0	8.00067	0	0	0.0094	0.0087	0.0232	0.000			
6	06Jan1940	244	8.00576	392	392	554.03	497	392	114	8.00558	114	86	0.0094	0.0087	0.0232	0.000			
7	07Jan1940	245	8.00553	234	234	553.99	0	234	486	4.97502	486	393	0.0094	0.0087	0.0232	0.000			
8	08Jan1940	312	8.00138	349	349	554.01	123	349	171	8.00138	171	250	0.0094	0.0087	0.0232	0.000			
9	09Jan1940	434	8.00939	321	321	554.02	397	321	126	8.00445	126	137	0.0094	0.0087	0.0232	0.000			
10	10Jan1940	407	8.00776	413	413	553.99	0	413	670	4.95146	670	534	0.0094	0.0087	0.0232	0.000			
11	11Jan1940	432	8.00924	400	400	554.01	260	400	97	8.00292	97	240	0.0094	0.0087	0.0232	0.000			
12	12Jan1940	370	8.00526	405	405	553.99	0	405	548	4.97057	548	435	0.0094	0.0087	0.0232	0.000			
13	13Jan1940	494	8.01020	419	419	554.02	335	419	123	8.00376	123	229	0.0094	0.0087	0.0232	0.000			
14	14Jan1940	443	8.01260	399	399	553.98	0	399	680	4.92797	680	541	0.0094	0.0087	0.0232	0.000			
15	15Jan1940	308	8.00524	385	385	554.00	0	385	167	4.99589	167	296	0.0094	0.0087	0.0232	0.000			
16	16Jan1940	424	8.00679	390	390	553.87	0	390	1541	4.48341	1541	1197	0.0094	0.0087	0.0232	0.000			
17	17Jan1940	455	8.01282	367	367	553.90	0	367	0	4.61478	0	385	0.0094	0.0087	0.0232	0.000			
18	18Jan1940	302	8.00873	338	338	553.93	0	338	0	4.73378	0	0	0.0094	0.0087	0.0232	0.000			
19	19Jan1940	286	8.00691	294	294	553.96	0	294	0	4.83413	0	0	0.0094	0.0087	0.0232	0.000			
20	20Jan1940	309	8.00939	265	265	553.97	0	265	67	4.89346	67	50	0.0094	0.0087	0.0232	0.000			
21	21Jan1940	280	8.00785	285	285	553.99	0	285	96	4.94909	96	89	0.0094	0.0087	0.0232	0.000			
22	22Jan1940	275	8.00777	262	262	554.00	0	262	118	4.98610	118	112	0.0094	0.0087	0.0232	0.000			
23	23Jan1940	277	8.00764	265	265	554.01	86	265	131	8.00097	131	128	0.0094	0.0087	0.0232	0.000			
24	24Jan1940	269	8.00598	275	275	554.02	306	275	107	8.00343	107	113	0.0094	0.0087	0.0232	0.000			
25	25Jan1940	291	8.00511	287	287	553.99	0	287	460	4.96792	460	372	0.0094	0.0087	0.0232	0.000			
26	26Jan1940	310	8.00616	283	283	554.00	33	283	133	8.00037	133	215	0.0094	0.0087	0.0232	0.000			
27	27Jan1940	294	8.00493	295	295	554.01	205	295	151	8.00230	151	146	0.0094	0.0087	0.0232	0.000			
28	28Jan1940	329	8.00707	289	289	554.02	414	289	126	8.00464	126	132	0.0094	0.0087	0.0232	0.000			
29	29Jan1940	293	8.00425	314	314	553.99	0	314	518	4.97749	518	420	0.0094	0.0087	0.0232	0.000			
30	30Jan1940	404	8.00905	331	331	554.01	254	331	92	8.00285	92	199	0.0094	0.0087	0.0232	0.000			
31	31Jan1940	454	8.00906	440	440	553.73	0	440	3031	3.93044	3031	2296	0.0094	0.0087	0.0232	0.000			
32	01Feb1940	609	8.01927	497	497	553.79	0	507	0	4.14142	0	758	-0.0207	-0.0507	-0.0376	0.000			
33	02Feb1940	604	8.01875	624	624	553.85	0	646	0	4.41167	0	0	-0.0207	-0.0507	-0.0376	0.000			
34	03Feb1940	615	8.02089	602	602	553.92	0	648	0	4.68285	0	0	-0.0207	-0.0507	-0.0376	0.000			
35	04Feb1940	577	8.01631	647	647	553.99	0	647	0	4.95357	0	0	-0.0207	-0.0507	-0.0376	0.000			
36	05Feb1940	576	8.01686	582	582	554.04	745	582	89	8.00835	89	66	-0.0207	-0.0507	-0.0376	0.000			
37	06Feb1940	499	8.01644	517	517	553.98	0	517	1105	4.90614	1105	851	-0.0207	-0.0507	-0.0376	0.000			
38	07Feb1940	374	8.00821	489	489	554.02	309	489	102	8.00347	102	353	-0.0207	-0.0507	-0.0376	0.000			
39	08Feb1940	430	8.00927	430	430	553.99	0	430	710	4.94358	710	558	-0.0207	-0.0507	-0.0376	0.000			
40	09Feb1940	549	8.01810	454	454	554.03	540	454	40	8.00606	40	207	-0.0207	-0.0507	-0.0376	0.000			
41	10Feb1940	444	8.00969	561	561	553.99	0	561	963	4.94139	963	732	-0.0207	-0.0507	-0.0376	0.000			
42	11Feb1940	507																	

		USACE SWT RiverWare Period-of-Record Model, Daily Time Series Data																	
Element	El Dorado	Kaw	Keystone	Birch	Skiatook	Hulah	Copan	Toronto	Fall River	Elk City	Big Hill	Oologah	Marion	Council Grove	John Redmond	Tenkkiller	Eufaula	Wister	
Parameter Units	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level	Operating Level
1	01Jan1940	5	5	5	5	4.99901	5	5	5	5	5	4.99	5	5	5	5	5	5	5
2	02Jan1940	5	5	5	5	4.99803	4.99	5	4.99	5	4.99	4.98	5	5	4.99	4.98	4.98	5	5
3	03Jan1940	5	5	4.98	5	4.99706	4.99	4.99	4.99	4.99	4.99	4.98	5	4.98	5	5	4.99	4.98	4.98
4	04Jan1940	5	5	4.96	4.99	4.99609	4.99	4.99	4.99	4.99	4.99	4.98	5	4.97	5	5	4.99	4.96	4.99
5	05Jan1940	5	5	4.96	4.99	4.99512	4.99	4.99	4.98	4.99	4.98	4.97	5	4.97	5	5	4.99	4.96	4.99
6	06Jan1940	5	5	4.96	4.99	4.99414	4.98	4.99	4.98	4.99	4.98	4.97	5	4.97	5	5	4.99	4.96	4.95
7	07Jan1940	5	5	4.96	4.99	4.99317	4.98	4.99	4.98	4.98	4.97	5	4.97	5	5	4.98	4.96	4.95	4.98
8	08Jan1940	5	5	4.96	4.99	4.99221	4.98	4.99	4.98	4.98	4.97	5	4.96	5	5	4.98	4.97	4.95	4.98
9	09Jan1940	5	5	4.94	4.99	4.99123	4.97	4.98	4.97	4.98	4.96	5	4.96	4.99	5	4.98	4.94	4.93	4.98
10	10Jan1940	4.99	5	4.94	4.98	4.99026	4.97	4.98	4.97	4.98	4.96	5	4.96	4.99	4.99	4.98	4.95	4.93	4.98
11	11Jan1940	4.99	5	4.94	4.98	4.9893	4.97	4.98	4.97	4.97	4.95	5	4.95	4.99	4.99	4.98	4.92	4.91	4.98
12	12Jan1940	4.99	5	4.94	4.98	4.98833	4.97	4.98	4.96	4.97	4.95	5	4.95	4.99	4.99	4.98	4.91	4.97	
13	13Jan1940	4.99	5	4.94	4.98	4.98736	4.96	4.98	4.96	4.97	4.95	5	4.95	4.99	4.99	4.98	4.9	4.91	4.97
14	14Jan1940	4.99	5	4.94	4.98	4.98639	4.96	4.98	4.96	4.97	4.94	4.99	4.95	4.99	4.99	4.98	4.91	4.91	4.97
15	15Jan1940	4.99	5	4.94	4.98	4.98542	4.96	4.97	4.95	4.96	4.94	4.99	4.94	4.99	4.99	4.97	4.91	4.91	4.97
16	16Jan1940	4.99	5	4.94	4.97	4.98445	4.96	4.97	4.95	4.96	4.93	4.99	4.94	4.99	4.99	4.97	4.91	4.89	4.97
17	17Jan1940	4.99	5	4.94	4.97	4.98348	4.95	4.97	4.95	4.96	4.93	4.99	4.94	4.99	4.99	4.97	4.91	4.89	4.97
18	18Jan1940	4.99	5	4.93	4.97	4.98251	4.95	4.97	4.94	4.96	4.93	4.99	4.93	4.99	4.99	4.97	4.89	4.86	4.96
19	19Jan1940	4.99	5	4.88	4.97	4.98154	4.95	4.97	4.94	4.95	4.92	4.99	4.93	4.99	4.99	4.97	4.87	4.86	4.96
20	20Jan1940	4.99	5	4.88	4.97	4.98057	4.94	4.97	4.94	4.95	4.92	4.99	4.92	4.99	4.99	4.97	4.87	4.86	4.96
21	21Jan1940	4.99	5	4.88	4.97	4.9796	4.94	4.96	4.94	4.95	4.91	4.99	4.92	4.99	4.99	4.96	4.87	4.86	4.96
22	22Jan1940	4.99	5	4.87	4.97	4.97863	4.94	4.96	4.93	4.95	4.91	4.99	4.92	4.99	4.99	4.96	4.87	4.86	4.95
23	23Jan1940	4.99	5	4.87	4.96	4.97766	4.94	4.96	4.93	4.94	4.91	4.99	4.92	4.99	4.99	4.96	4.88	4.86	4.95
24	24Jan1940	4.99	5	4.86	4.96	4.97669	4.93	4.96	4.93	4.94	4.9	4.99	4.91	4.99	4.99	4.96	4.85	4.84	4.95
25	25Jan1940	4.99	5	4.86	4.96	4.97572	4.93	4.96	4.92	4.94	4.9	4.99	4.91	4.98	4.99	4.96	4.83	4.82	4.95
26	26Jan1940	4.99	5	4.86	4.96	4.97475	4.93	4.96	4.92	4.94	4.89	4.99	4.91	4.98	4.99	4.96	4.83	4.82	4.95
27	27Jan1940	4.99	5	4.86	4.96	4.97377	4.92	4.96	4.92	4.93	4.89	4.99	4.9	4.98	4.99	4.95	4.83	4.82	4.94
28	28Jan1940	4.99	5	4.84	4.96	4.9728	4.92	4.95	4.91	4.93	4.88	4.99	4.9	4.98	4.99	4.95	4.84	4.82	4.94
29	29Jan1940	4.98	5	4.84	4.95	4.97183	4.92	4.95	4.91	4.93	4.88	4.99	4.9	4.98	4.99	4.95	4.81	4.8	4.94
30	30Jan1940	4.98	5	4.84	4.95	4.97086	4.92	4.95	4.91	4.93	4.88	4.99	4.9	4.98	4.98	4.95	4.82	4.8	4.94
31	31Jan1940	4.98	5	4.84	4.95	4.96989	4.91	4.95	4.91	4.92	4.87	4.99	4.9	4.98	4.98	4.95	4.82	4.8	4.93
32	01Feb1940	4.98	5	4.84	4.95	4.96933	4.91	4.95	4.9	4.92	4.87	4.99	4.9	4.98	4.98	4.95	4.79	4.79	4.93
33	02Feb1940	4.98	5	4.84	4.95	4.96878	4.91	4.95	4.9	4.92	4.86	4.99	4.89	4.98	4.98	4.94	4.8	4.79	4.93
34	03Feb1940	4.98	5	4.85	4.95	4.96822	4.91	4.95	4.9	4.92	4.86	4.99	4.89	4.98	4.98	4.94	4.8	4.79	4.93
35	04Feb1940	4.98	5	4.85	4.95	4.96766	4.91	4.95	4.89	4.91	4.86	4.99	4.89	4.98	4.98	4.94	4.8	4.79	4.93
36	05Feb1940	4.98	5	4.86	4.95	4.9671	4.91	4.94	4.89	4.91	4.85	4.99	4.88	4.98	4.98	4.94	4.8	4.79	4.93
37	06Feb1940	4.98	5	4.81	4.95	4.96654	4.9	4.94	4.89	4.91	4.85	4.99	4.88	4.98	4.98	4.94	4.8	4.77	4.93
38	07Feb1940	4.98	5	4.82	4.95	4.96598	4.9	4.94	4.88	4.91	4.85</								

**Pensacola**

Elevation ft PD	Area acre	Storage acre-ft	Elevation ft PD	OPEVEL 1 - 16.1	Max Regulated Spill cfs			Induced Surcharge cfs
					Elevation ft PD	Spill cfs	Surcharge cfs	
612	0	0	612	1	612	0	0	
613	1	0.3	705.5	2	633	0	0	
614	6	3.5	705.5001	3	730	1	0	
615	30	15	727.8	4	735	47200	0	
616	36	48	742	5	740	84500	0	
617	42	86	742.0001	6	742	117000	0	
618	51	132	742.0002	7	745.01	190000	0	
619	66	190	742.0003	8	745.5	204000	0	
620	128	269	743.49	9	745.95	217000	0	
621	144	406	746.52	10	748	278000	0	
622	158	556	749.21	11	752.4	422000	0	
623	174	722	751.66	12	754	484000	0	
624	196	906	753.92	13	754.8	515000	13500	
625	269	1126	755	14	754.85	518000	50000	
626	298	1411	755.6	15	754.9	520800	100000	
627	329	1724	757	16	754.95	523700	200000	
628	365	2070	758	16.1	754.98	525400	300000	
629	402	2453			754.99	526000	500000	
630	471	2879			755	527000	525000	
631	502	3366			756	557000	550000	
632	529	3882			756.7	567200	567200	
633	556	4425			757	614900	614900	
634	587	4996			758	700000	700000	
635	653	5601						
636	687	6270						
637	728	6977						
638	781	7731						
639	837	8539						
640	924	9408						
641	967	10354						
642	1007	11341						
643	1054	12371						
644	1105	13450						
645	1231	14594						
646	1328	15876						
647	1420	17250						
648	1531	18723						
649	1658	20317						
650	1863	22045						
651	1995	23978						
652	2118	26035						
653	2226	28209						
654	2335	30489						
655	2500	32884						
656	2608	35441						
657	2721	38105						
658	2834	40883						
659	2956	43776						
660	3137	46798						
661	3277	50008						
662	3407	53350						
663	3544	56826						
664	3699	60446						
665	3954	64239						
666	4160	68300						
667	4350	72556						
668	4537	77000						
669	4741	81636						
670	5029	86486						
671	5249	91629						
672	5459	96984						
673	5674	102550						
674	5896	108336						
675	6189	114350						
676	6454	120680						
677	6678	127249						
678	6904	134040						
679	7136	141059						
680	7442	148319						
681	7687	155888						
682	7934	163699						
683	8201	171765						
684	8484	180108						
685	8854	188752						
686	9195	197780						
687	9535	207146						
688	9860	216848						
689	10160	226859						
690	10533	237178						
691	10828	247869						
692	11112	258838						
693	11420	270099						
694	11747	281679						
695	12154	293602						

**Hudson**

Elevation ft M.S.L.	Area acre	Storage acre-ft	Elevation ft M.S.L.	OPEVEL 1 - 16.1	Elevation ft M.S.L.	OPEVEL 1 - 16.1	Elevation ft M.S.L.	Max Regulated Spill cfs	Induced Surcharge cfs
558	0	0	558	1	558	1	558	0	0
559	1	1	618.5	2	599	29000	599	29000	0
560	1.5	2	618.5	3	610	82800	610	82800	0
561	2	3	618.5	4	619	220000	619	220000	0
562	9	8	619	5	624	315000	624	315000	0
563	22	23	619.001	6	630	449000	630	449000	0
564	59	57	619.002	7	633	527500	633	527500	0
565	74	127	619.003	8	635	583100	635	583100	70000
566	80	204	621.16	9	635.43	594000	635.43	594000	85000
567	93	290	625.12	10	635.77	606000	635.77	606000	100000
568	119	395	628.65	11	635.94	611000	635.94	611000	360000
569	184	535	631.81	12	635.99	612000	635.99	612000	500000
570	221	745	634.66	13	636	613000	636	613000	613000
571	240	975	636	14	645	884000	645	884000	884000
572	262	1226	636.001	15	648	974333	648	974333	974333
573	289	1501			648	16.1			
574	337	18							

**Pensacola**

Elevation ft PD	Area acre	Storage acre-ft	Elevation ft PD	OPEVEL 1 - 16.1	Elevation ft PD	Max Regulated Spill cfs	Induced Surcharge cfs
696	12490	305932					
697	12813	318584					
698	13142	331561					
699	13487	344873					
700	13934	358558					
701	14259	372661					
702	14550	387069					
703	14846	401769					
704	15157	416769					
705	15584	432106					
706	15921	447863					
707	16263	463955					
708	16629	480402					
709	17016	497224					
710	17556	514468					
711	18036	532267					
712	18520	550554					
713	18986	569302					
714	19509	588551					
715	20190	608359					
716	20726	628825					
717	21262	649820					
718	21830	671364					
719	22478	693521					
720	23244	716333					
721	23859	739896					
722	24443	764054					
723	25007	788782					
724	25592	814081					
725	26354	840006					
726	26991	866684					
727	27655	894007					
728	28359	922021					
729	29035	950728					
730	29745	980096					
731	30386	1010168					
732	31052	1040888					
733	31788	1072304					
734	32607	1104503					
735	33530	1137530					
736	34275	1171445					
737	34989	1206086					
738	35760	1241453					
739	36638	1277662					
740	37788	1314761					
741	38918	1353101					
742	40021	1392678					
743	40636	1433025					
744	41221	1473920					
745	41779	1515412					
746	43551	1558073					
747	45323	1602507					
748	47095	1648714					
749	48867	1696692					
750	50639	1746443					
751	52411	1797965					
752	54184	1851261					
753	55956	1906328					
754	57728	1963167					
755	59300	2021679					
756	61100	2081877					
757	62950	2143900					
758	64800	2207773					

**Hudson**

Elevation ft M.S.L.	Area acre	Storage acre-ft	Elevation ft M.S.L.	OPEVEL 1 - 16.1	Elevation ft M.S.L.	Max Regulated Spill cfs	Induced Surcharge cfs
641	22375	547111					
642	23120	569858					
643	23870	593352					
644	24620	617596					
645	25400	642605					
648	27910	722482					

**Parsons-Commerce**

Routing Coefficients	
Lag Coeff	
1	0.353
2	0.4568
3	0.1344
4	0.0395
5	0.0116
6	0.0034
7	0.001
8	0.0003

**Commerce-Pensacola**

Routing Coefficients	
Lag Coeff	
1	0.6
2	0.4

**Pensacola-Hudson**

Routing Coefficients	
Lag Coeff	
1	1
2	1

**Hudson-Ft Gibson**

Routing Coefficients	
Lag Coeff	
1	1
2	1

## **Appendix B. Operations Model Input Data**

---

# HEAD LOSS CALCULATIONS - 1 OF 6

Component	Pipe Size (ft)	Description	Reference for Headloss Estimation	Minor Losses			Total Headloss	
				Kv (ft <sup>2</sup> )	A (ft)	L (ft)	Kq (cfs)	hL (ft)
Trashrack	---	Trashrack losses neglected: very large area, low velocity	---	---	---	---	---	---
Inlet	15x15	Standard sharp-edged inlet loss	---	0.50	225.00	---	1.54E-07	2505 0.96
Contraction: 15' sq. to 15' diam.	15	Area 1 = 225.0 ft <sup>2</sup> ; Area 2 = 176.7 ft <sup>2</sup> ; A2/A1 = 0.78	[USACE HDC 228-4]	0.07	176.71	---	3.49E-08	2505 0.22
42° bend	15	r = 75'; Assume r/D=5	[USACE HDC 228-1]	0.075	176.71	---	3.74E-08	2505 0.23
Butterfly Valve	15	15' Diameter Butterfly Valve	[USACE HDC 331-1]	0.34	176.71	---	1.68E-07	2505 1.06
Penstock Friction	15	194' +/- Total Length	Darcy-Weisbach	---	---	194	5.58E-08	2505 0.35
				Totals:			4.50E-07	2505 2.82

## Governing Equations:

$$H = Q^2 / (C^2 * A^2 * 2g) \quad \text{where:}$$

$$Q = C * A * (2gH)^{1/2}$$

$$A = B * Go$$

$$H = Kv * V^2 / (2g)$$

$$Q = A * (2gH/Kv)^{1/2}$$

$$Kv = 1/C^2$$

$$H = Q^2 * Kq$$

$$Q = (H/Kq)^{1/2}$$

$$Kq = 1/(C^2 * A^2 * 2g)$$

$g$  (gravity constant) = 32.146 ft/s<sup>2</sup> [HDC 000-1]

H = energy head immediately upstream of gate, measured to centerline

Q = gate discharge (cfs)

A = open area of gate (ft<sup>2</sup>)

B = gate width (feet)

Go = gate vertical opening (feet)

V = velocity through open area of gate (ft/s)


C = discharge coefficient

Kv = gate valve loss coefficient (velocity-based)

Kq = gate valve loss coefficient (discharge-based)

Site Latitude = 36.5 deg

Site Elevation = 750 feet



## HEAD LOSS CALCULATIONS - 2 OF 6

Darcy-Weisbach Resistance Coefficients for Various Pipe Sizes and Discharges

Discharge (cfs)	Conduit Diameter (feet)	Gravity Constant	Wetted Area (ft <sup>2</sup> )	Wetted Perimeter (feet)	Hydraulic Diameter (feet)	Velocity (ft/sec)	Fluid Type	Kinematic Viscosity ft <sup>2</sup> /s		Specific Weight	Reynolds Number	Conduit Material	Relative Roughness (feet)	Laminar Zone (f)			
								3	2					Conduit Material	Relative Roughness (feet)	Laminar Zone (f)	Critical Zone (f)
1	15	32.14577	176.71	47.12	15	0.0	Water, 50° F	1.41E-05	1.41E-05	1.94	62.36	6.03E+03	Steel or wrought Iron	0.00015	1.00E-05	0.010609	indeterminate
2	15	32.14577	176.71	47.12	15	0.0		1.41E-05	1.41E-05	1.94	62.36	1.21E+04		0.00015	1.00E-05	0.005304	indeterminate
3	15	32.14577	176.71	47.12	15	0.0		1.41E-05	1.41E-05	1.94	62.36	1.81E+04		0.00015	1.00E-05	0.003536	indeterminate
10	15	32.14577	176.71	47.12	15	0.1		1.41E-05	1.41E-05	1.94	62.36	6.03E+04		0.00015	1.00E-05	0.001061	indeterminate
20	15	32.14577	176.71	47.12	15	0.1		1.41E-05	1.41E-05	1.94	62.36	1.21E+05		0.00015	1.00E-05	0.000530	indeterminate
30	15	32.14577	176.71	47.12	15	0.2		1.41E-05	1.41E-05	1.94	62.36	1.81E+05		0.00015	1.00E-05	0.000354	indeterminate
40	15	32.14577	176.71	47.12	15	0.2		1.41E-05	1.41E-05	1.94	62.36	2.41E+05		0.00015	1.00E-05	0.000265	indeterminate
50	15	32.14577	176.71	47.12	15	0.3		1.41E-05	1.41E-05	1.94	62.36	3.02E+05		0.00015	1.00E-05	0.000212	indeterminate
75	15	32.14577	176.71	47.12	15	0.4		1.41E-05	1.41E-05	1.94	62.36	4.52E+05		0.00015	1.00E-05	0.000141	indeterminate
100	15	32.14577	176.71	47.12	15	0.6		1.41E-05	1.41E-05	1.94	62.36	6.03E+05		0.00015	1.00E-05	0.000106	indeterminate
150	15	32.14577	176.71	47.12	15	0.8		1.41E-05	1.41E-05	1.94	62.36	9.05E+05		0.00015	1.00E-05	0.000071	indeterminate
200	15	32.14577	176.71	47.12	15	1.1		1.41E-05	1.41E-05	1.94	62.36	1.21E+06		0.00015	1.00E-05	0.000053	indeterminate
400	15	32.14577	176.71	47.12	15	2.3		1.41E-05	1.41E-05	1.94	62.36	2.41E+06		0.00015	1.00E-05	0.000027	indeterminate
600	15	32.14577	176.71	47.12	15	3.4		1.41E-05	1.41E-05	1.94	62.36	3.62E+06		0.00015	1.00E-05	0.000018	indeterminate
800	15	32.14577	176.71	47.12	15	4.5		1.41E-05	1.41E-05	1.94	62.36	4.83E+06		0.00015	1.00E-05	0.000013	indeterminate
1000	15	32.14577	176.71	47.12	15	5.7		1.41E-05	1.41E-05	1.94	62.36	6.03E+06		0.00015	1.00E-05	0.000011	indeterminate
1200	15	32.14577	176.71	47.12	15	6.8		1.41E-05	1.41E-05	1.94	62.36	7.24E+06		0.00015	1.00E-05	0.000009	indeterminate
1400	15	32.14577	176.71	47.12	15	7.9		1.41E-05	1.41E-05	1.94	62.36	8.45E+06		0.00015	1.00E-05	0.000008	indeterminate
1600	15	32.14577	176.71	47.12	15	9.1		1.41E-05	1.41E-05	1.94	62.36	9.65E+06		0.00015	1.00E-05	0.000007	indeterminate
1800	15	32.14577	176.71	47.12	15	10.2		1.41E-05	1.41E-05	1.94	62.36	1.09E+07		0.00015	1.00E-05	0.000006	indeterminate
2000	15	32.14577	176.71	47.12	15	11.3		1.41E-05	1.41E-05	1.94	62.36	1.21E+07		0.00015	1.00E-05	0.000005	indeterminate
2200	15	32.14577	176.71	47.12	15	12.4		1.41E-05	1.41E-05	1.94	62.36	1.33E+07		0.00015	1.00E-05	0.000005	indeterminate
2400	15	32.14577	176.71	47.12	15	13.6		1.41E-05	1.41E-05	1.94	62.36	1.45E+07		0.00015	1.00E-05	0.000004	indeterminate
2600	15	32.14577	176.71	47.12	15	14.7		1.41E-05	1.41E-05	1.94	62.36	1.57E+07		0.00015	1.00E-05	0.000004	indeterminate
2800	15	32.14577	176.71	47.12	15	15.8		1.41E-05	1.41E-05	1.94	62.36	1.69E+07		0.00015	1.00E-05	0.000004	indeterminate
3000	15	32.14577	176.71	47.12	15	17.0		1.41E-05	1.41E-05	1.94	62.36	1.81E+07		0.00015	1.00E-05	0.000004	indeterminate

## HEAD LOSS CALCULATIONS - 3 OF 6


Smooth Pipes				Transition Zone				y-Weisbach Resistance				Friction Slope Factors		Headloss Coefficients (K)		Loss per Unit Length of Co			
Guess Value	Left Half Equation	Right Half Equation	Difference	Guess Value	Left Half Equation	Right Half Equation	Difference	Rough Pipes	Rough Pipe Limit	Flow Regime	Selected Coeff.	Discharge (cfs)	15' Dia. Steel	Discharge (cfs)	15' Dia. Steel	Discharge (cfs)	15' Dia. Steel	Discharge (cfs)	15' Dia. Steel
(f)	<0.001			(f)	<0.001			(f)	(Re)			0	0.03546	0	0.00E+00	0	1.17E-09	0	0.00E+00
0.035456	5.31074	5.31074	0.0000	0.035461	5.31039	5.31039	0.0000	0.008061	2.23E+08	Transition	0.035461	1	0.03546	1	1.17E-09	1	1.17E-09	1	1.17E-09
0.029406	5.83154	5.83154	0.0000	0.029417	5.83044	5.83044	0.0000	0.008061	2.23E+08	Transition	0.029417	2	0.02942	2	3.87E-09	2	9.68E-10	2	3.87E-09
0.026533	6.13908	6.13908	0.0000	0.026549	6.13726	6.13726	0.0000	0.008061	2.23E+08	Transition	0.026549	3	0.02655	3	7.87E-09	3	8.74E-10	3	7.87E-09
0.020045	7.06306	7.06306	0.0000	0.020082	7.05659	7.05659	0.0000	0.008061	2.23E+08	Transition	0.020082	10	0.02008	10	6.61E-08	10	6.61E-10	10	6.61E-08
0.017307	7.60133	7.60133	0.0000	0.017364	7.58876	7.58875	0.0000	0.008061	2.23E+08	Transition	0.017364	20	0.01736	20	2.29E-07	20	5.72E-10	20	2.29E-07
0.015950	7.91805	7.91806	0.0000	0.016024	7.89967	7.89967	0.0000	0.008061	2.23E+08	Transition	0.016024	30	0.01602	30	4.75E-07	30	5.28E-10	30	4.75E-07
0.015079	8.14354	8.14354	0.0000	0.015168	8.11954	8.11954	0.0000	0.008061	2.23E+08	Transition	0.015168	40	0.01517	40	7.99E-07	40	4.99E-10	40	7.99E-07
0.014450	8.31886	8.31886	0.0000	0.014553	8.28939	8.28939	0.0000	0.008061	2.23E+08	Transition	0.014553	50	0.01455	50	1.20E-06	50	4.79E-10	50	1.20E-06
0.013401	8.63831	8.63831	0.0000	0.013535	8.59563	8.59563	0.0000	0.008061	2.23E+08	Transition	0.013535	75	0.01353	75	2.51E-06	75	4.46E-10	75	2.51E-06
0.012723	8.86563	8.86563	0.0000	0.012883	8.81025	8.81025	0.0000	0.008061	2.23E+08	Transition	0.012883	100	0.01288	100	4.24E-06	100	4.24E-10	100	4.24E-06
0.011848	9.18689	9.18689	0.0000	0.012057	9.10727	9.10727	0.0000	0.008061	2.23E+08	Transition	0.012057	150	0.01206	150	8.93E-06	150	3.97E-10	150	8.93E-06
0.011280	9.41543	9.41543	0.0000	0.011530	9.31274	9.31274	0.0000	0.008061	2.23E+08	Transition	0.011530	200	0.01153	200	1.52E-05	200	3.80E-10	200	1.52E-05
0.010064	9.96796	9.96796	0.0000	0.010452	9.78138	9.78138	0.0000	0.008061	2.23E+08	Transition	0.010452	400	0.01045	400	5.51E-05	400	3.44E-10	400	5.51E-05
0.009440	10.29232	10.29233	0.0000	0.009937	10.03147	10.03147	0.0000	0.008061	2.23E+08	Transition	0.009937	600	0.00994	600	1.18E-04	600	3.27E-10	600	1.18E-04
0.009031	10.52295	10.52295	0.0000	0.009621	10.19489	10.19489	0.0000	0.008061	2.23E+08	Transition	0.009621	800	0.00962	800	2.03E-04	800	3.17E-10	800	2.03E-04
0.008731	10.70211	10.70211	0.0000	0.009403	10.31245	10.31245	0.0000	0.008061	2.23E+08	Transition	0.009403	1000	0.00940	1000	3.10E-04	1000	3.10E-10	1000	3.10E-04
0.008497	10.84866	10.84866	0.0000	0.009242	10.40205	10.40205	0.0000	0.008061	2.23E+08	Transition	0.009242	1200	0.00924	1200	4.38E-04	1200	3.04E-10	1200	4.38E-04
0.008306	10.97268	10.97268	0.0000	0.009117	10.47306	10.47306	0.0000	0.008061	2.23E+08	Transition	0.009117	1400	0.00912	1400	5.88E-04	1400	3.00E-10	1400	5.88E-04
0.008145	11.08020	11.08019	0.0000	0.009017	10.53095	10.53095	0.0000	0.008061	2.23E+08	Transition	0.009017	1600	0.00902	1600	7.60E-04	1600	2.97E-10	1600	7.60E-04
0.008008	11.17509	11.17509	0.0000	0.008935	10.57918	10.57918	0.0000	0.008061	2.23E+08	Transition	0.008935	1800	0.00894	1800	9.53E-04	1800	2.94E-10	1800	9.53E-04
0.007887	11.26003	11.26003	0.0000	0.008666	10.62006	10.62006	0.0000	0.008061	2.23E+08	Transition	0.008866	2000	0.00887	2000	1.17E-03	2000	2.92E-10	2000	1.17E-03
0.007781	11.33691	11.33691	0.0000	0.008808	10.65521	10.65521	0.0000	0.008061	2.23E+08	Transition	0.008808	2200	0.00881	2200	1.40E-03	2200	2.90E-10	2200	1.40E-03
0.007685	11.40712	11.40712	0.0000	0.008758	10.68577	10.68577	0.0000	0.008061	2.23E+08	Transition	0.008758	2400	0.00876	2400	1.66E-03	2400	2.88E-10	2400	1.66E-03
0.007599	11.47174	11.47174	0.0000	0.008714	10.71262	10.71262	0.0000	0.008061	2.23E+08	Transition	0.008714	2600	0.00871	2600	1.94E-03	2600	2.87E-10	2600	1.94E-03
0.007520	11.53159	11.53159	0.0000	0.008675	10.73640	10.73640	0.0000	0.008061	2.23E+08	Transition	0.008675	2800	0.00868	2800	2.24E-03	2800	2.86E-10	2800	2.24E-03
0.007448	11.58733	11.58733	0.0000	0.008641	10.75763	10.75763	0.0000	0.008061	2.23E+08	Transition	0.008641	3000	0.00864	3000	2.56E-03	3000	2.84E-10	3000	2.56E-03
								99999	0.00864			99999	2.56E-03	99999	2.84E-10	99999	2.84E+00		

$$y=ax^2+bx; \text{ where } y=\text{headloss per foot}, x=\text{discharge}, \text{ and } a/b \text{ are constants determined from trendline equation}$$


a = 2.73183E-10

b = 3.66363E-08

## HEAD LOSS CALCULATIONS - 4 OF 6



## HEAD LOSS CALCULATIONS - 5 OF 6




## HEAD LOSS CALCULATIONS - 6 OF 6

### Computed Discharge-Based Headloss Coefficients, $K_q$ per Unit Length of Conduit

■ 15' Dia. Steel

Assumptions:  
1) Water at 50°F  
2) Gravity = 32.15 ft/s<sup>2</sup>  
3) Roughness,  $k$  = 0.00015 feet (steel)



**Pensacola Turbine-Generator Efficiency Hill Curve with Air Valves Closed**

Discharge (cfs)	Total Turbine-Generator Efficiency (%) vs. Net Head (ft)												
	0	95	100	105	110	115	117.5	120	125	130	135	140	999
0	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
700	0.0%	60.6%	54.1%	47.3%	40.4%	32.9%	28.3%	23.9%	16.2%	12.9%	12.2%	11.6%	0.0%
750	0.0%	68.2%	63.5%	56.2%	50.6%	45.1%	42.4%	39.7%	34.6%	31.9%	31.3%	30.6%	0.0%
800	0.0%	72.6%	72.0%	66.4%	60.9%	55.4%	52.7%	50.2%	47.2%	46.0%	45.6%	45.2%	0.0%
850	0.0%	74.8%	75.1%	74.5%	71.8%	65.9%	63.2%	61.5%	58.5%	57.7%	57.4%	57.0%	0.0%
900	0.0%	76.5%	77.0%	77.0%	75.7%	73.9%	73.4%	72.5%	69.9%	69.6%	69.2%	68.9%	0.0%
950	0.0%	77.7%	78.4%	78.6%	77.9%	76.4%	76.0%	75.5%	74.8%	74.4%	74.3%	74.3%	0.0%
1000	0.0%	78.7%	79.6%	79.9%	79.4%	78.3%	77.8%	77.5%	76.6%	76.0%	75.7%	75.5%	0.0%
1050	0.0%	79.3%	80.4%	81.0%	80.6%	79.7%	79.4%	79.0%	78.1%	77.4%	77.0%	76.7%	0.0%
1100	0.0%	79.7%	80.8%	81.6%	81.5%	80.9%	80.6%	80.2%	79.5%	78.7%	78.3%	77.9%	0.0%
1150	0.0%	80.0%	81.2%	81.9%	82.2%	81.8%	81.6%	81.3%	80.6%	80.0%	79.5%	79.1%	0.0%
1200	0.0%	80.4%	81.4%	82.2%	82.9%	82.6%	82.3%	82.1%	81.7%	81.1%	80.6%	80.2%	0.0%
1250	0.0%	80.8%	81.6%	82.5%	83.3%	83.3%	83.1%	82.9%	82.5%	82.1%	81.7%	81.2%	0.0%
1300	0.0%	81.2%	81.9%	82.8%	83.6%	84.0%	83.8%	83.7%	83.4%	83.0%	82.6%	82.2%	0.0%
1350	0.0%	81.7%	82.4%	83.2%	83.9%	84.5%	84.4%	84.3%	84.1%	83.8%	83.5%	83.1%	0.0%
1400	0.0%	82.2%	82.9%	83.6%	84.2%	84.8%	85.0%	84.9%	84.8%	84.5%	84.3%	84.0%	0.0%
1450	0.0%	82.7%	83.5%	84.1%	84.6%	85.1%	85.3%	85.5%	85.5%	85.3%	85.0%	84.7%	0.0%
1500	0.0%	83.2%	84.0%	84.7%	85.2%	85.7%	85.9%	86.1%	86.2%	86.0%	85.7%	85.4%	0.0%
1550	0.0%	83.8%	84.6%	85.3%	85.8%	86.2%	86.5%	86.6%	86.8%	86.7%	86.4%	86.1%	0.0%
1600	0.0%	84.7%	85.4%	86.0%	86.5%	86.9%	87.0%	87.2%	87.4%	87.4%	87.1%	86.8%	0.0%
1650	0.0%	85.6%	86.2%	86.8%	87.2%	87.5%	87.6%	87.7%	88.0%	88.1%	87.8%	87.5%	0.0%
1700	0.0%	86.5%	87.0%	87.6%	88.0%	88.2%	88.3%	88.4%	88.7%	88.8%	88.6%	88.2%	0.0%
1750	0.0%	87.4%	88.0%	88.5%	88.9%	88.9%	89.0%	89.1%	89.4%	89.6%	89.4%	89.0%	0.0%
1800	0.0%	88.5%	88.9%	89.3%	89.6%	89.9%	89.9%	90.0%	90.1%	90.2%	90.2%	89.7%	0.0%
1850	0.0%	89.5%	89.7%	90.1%	90.4%	90.6%	90.7%	90.8%	90.8%	90.8%	90.8%	90.5%	0.0%
1900	0.0%	90.0%	90.5%	90.8%	91.1%	91.2%	91.3%	91.4%	91.4%	91.4%	91.3%	91.0%	0.0%
1950	0.0%	89.9%	90.7%	91.3%	91.5%	91.6%	91.7%	91.8%	91.9%	91.8%	91.8%	91.5%	0.0%
2000	0.0%	89.5%	90.0%	91.0%	91.3%	91.5%	91.6%	91.7%	91.9%	92.0%	91.8%	91.4%	0.0%
2050	0.0%	89.1%	89.5%	90.3%	90.9%	91.2%	91.3%	91.4%	91.5%	91.6%	91.7%	91.3%	0.0%
2100	0.0%	88.5%	89.1%	89.6%	90.4%	90.6%	90.8%	91.0%	91.1%	91.2%	91.3%	91.1%	0.0%
2150	0.0%	87.7%	88.7%	89.2%	89.8%	90.2%	90.3%	90.4%	90.7%	90.8%	90.8%	90.7%	0.0%
2200	0.0%	87.0%	88.0%	88.7%	89.3%	89.8%	89.9%	90.0%	90.1%	90.3%	90.4%	90.5%	0.0%
2250	0.0%	86.2%	87.2%	88.1%	88.8%	89.4%	89.6%	89.7%	89.8%	89.9%	90.0%	90.2%	0.0%
2300	0.0%	85.5%	86.5%	87.4%	88.2%	88.9%	89.1%	89.3%	89.4%	89.5%	89.7%	89.8%	0.0%
2350	0.0%	84.6%	85.7%	86.6%	87.5%	88.2%	88.5%	88.7%	89.0%	89.2%	89.2%	89.3%	0.0%
2400	0.0%	83.6%	84.8%	85.8%	86.7%	87.5%	87.8%	88.0%	88.4%	88.7%	88.8%	88.7%	0.0%
2450	0.0%	82.3%	83.7%	84.9%	85.9%	86.7%	87.0%	87.3%	87.7%	88.1%	88.3%	88.1%	0.0%
2500	0.0%	80.7%	82.5%	83.9%	84.9%	85.7%	86.0%	86.4%	86.9%	87.4%	87.6%	87.5%	0.0%
2550	0.0%	78.0%	80.9%	82.5%	83.7%	84.6%	85.0%	85.4%	86.0%	86.6%	86.8%	86.9%	0.0%
2600	0.0%	74.7%	78.1%	80.7%	82.3%	83.4%	83.9%	84.3%	85.0%	85.6%	85.9%	86.0%	0.0%

**Pensacola Turbine-Generator Efficiency Hill Curve with Air Valves Fully Open (90 degrees open)**


Discharge (cfs)	Total Turbine-Generator Efficiency (%) vs. Net Head (ft)												
	0	95	100	105	110	115	117.5	120	125	130	135	140	999
0	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%	0.0%
700	0.0%	40.3%	36.0%	31.5%	26.9%	21.9%	18.9%	15.9%	10.8%	8.6%	8.1%	7.7%	0.0%
750	0.0%	38.0%	35.4%	31.3%	28.2%	25.1%	23.7%	22.2%	19.3%	17.8%	17.5%	17.1%	0.0%
800	0.0%	39.1%	38.8%	35.8%	32.8%	29.9%	28.4%	27.1%	25.5%	24.8%	24.6%	24.4%	0.0%
850	0.0%	39.4%	39.6%	39.2%	37.8%	34.7%	33.3%	32.4%	30.8%	30.4%	30.2%	30.0%	0.0%
900	0.0%	39.7%	40.0%	40.0%	39.3%	38.3%	38.1%	37.6%	36.3%	36.1%	35.9%	35.7%	0.0%
950	0.0%	44.0%	44.4%	44.4%	44.0%	43.2%	43.0%	42.7%	42.3%	42.1%	42.0%	42.0%	0.0%
1000	0.0%	48.4%	48.9%	49.1%	48.8%	48.1%	47.9%	47.6%	47.1%	46.7%	46.6%	46.4%	0.0%
1050	0.0%	50.7%	51.4%	51.8%	51.6%	51.0%	50.8%	50.6%	50.0%	49.6%	49.3%	49.1%	0.0%
1100	0.0%	53.1%	53.9%	54.4%	54.4%	54.0%	53.8%	53.5%	53.0%	52.6%	52.3%	52.0%	0.0%
1150	0.0%	55.6%	56.4%	56.9%	57.1%	56.9%	56.7%	56.6%	56.1%	55.6%	55.3%	55.0%	0.0%
1200	0.0%	58.2%	58.9%	59.5%	60.1%	59.9%	59.7%	59.5%	59.2%	58.8%	58.4%	58.1%	0.0%
1250	0.0%	60.9%	61.5%	62.2%	62.8%	62.8%	62.6%	62.5%	62.1%	61.8%	61.5%	61.2%	0.0%
1300	0.0%	63.5%	64.1%	64.8%	65.4%	65.7%	65.6%	65.5%	65.2%	64.9%	64.6%	64.3%	0.0%
1350	0.0%	66.4%	66.9%	67.5%	68.1%	68.6%	68.5%	68.4%	68.2%	68.0%	67.7%	67.4%	0.0%
1400	0.0%	69.2%	69.8%	70.3%	70.8%	71.3%	71.5%	71.4%	71.2%	71.1%	70.9%	70.6%	0.0%
1450	0.0%	72.2%	72.9%	73.4%	73.9%	74.3%	74.5%	74.6%	74.6%	74.4%	74.2%	74.0%	0.0%
1500	0.0%	75.1%	75.8%	76.4%	76.8%	77.3%	77.5%	77.7%	77.7%	77.6%	77.5%	77.2%	0.0%
1550	0.0%	77.7%	78.4%	79.1%	79.5%	79.9%	80.1%	80.3%	80.5%	80.4%	80.2%	79.9%	0.0%
1600	0.0%	79.7%	80.3%	80.9%	81.4%	81.7%	81.9%	82.1%	82.3%	82.2%	82.0%	81.8%	0.0%
1650	0.0%	81.3%	81.9%	82.4%	82.8%	83.1%	83.2%	83.3%	83.6%	83.7%	83.4%	83.2%	0.0%
1700	0.0%	82.2%	82.7%	83.3%	83.7%	83.8%	83.9%	84.1%	84.4%	84.5%	84.3%	83.9%	0.0%
1750	0.0%	82.7%	83.3%	83.8%	84.3%	84.3%	84.3%	84.5%	84.8%	84.9%	84.7%	84.4%	0.0%
1800	0.0%	83.3%	83.8%	84.2%	84.5%	84.7%	84.8%	84.9%	85.0%	85.1%	85.1%	84.7%	0.0%
1850	0.0%	84.0%	84.3%	84.7%	85.0%	85.1%	85.3%	85.4%	85.3%	85.4%	85.4%	85.0%	0.0%
1900	0.0%	84.3%	84.8%	85.1%	85.4%	85.5%	85.6%	85.7%	85.7%	85.7%	85.6%	85.3%	0.0%
1950	0.0%	83.9%	84.6%	85.2%	85.3%	85.5%	85.6%	85.7%	85.7%	85.7%	85.7%	85.5%	0.0%
2000	0.0%	83.2%	83.7%	84.6%	85.0%	85.1%	85.2%	85.3%	85.5%	85.6%	85.5%	85.2%	0.0%
2050	0.0%	82.3%	82.7%	83.4%	84.0%	84.3%	84.4%	84.5%	84.6%	84.8%	84.9%	84.6%	0.0%
2100	0.0%	81.3%	81.9%	82.4%	83.1%	83.4%	83.5%	83.6%	83.8%	83.9%	84.1%	83.9%	0.0%
2150	0.0%	80.1%	81.0%	81.5%	82.1%	82.4%	82.5%	82.6%	82.9%	83.1%	83.2%	83.1%	0.0%
2200	0.0%	78.6%	79.5%	80.2%	80.8%	81.2%	81.3%	81.4%	81.6%	81.8%	82.0%	82.1%	0.0%
2250	0.0%	77.1%	78.0%	78.8%	79.5%	80.0%	80.1%	80.3%	80.5%	80.7%	80.9%	81.0%	0.0%
2300	0.0%	75.7%	76.6%	77.4%	78.1%	78.8%	79.0%	79.2%	79.4%	79.6%	79.8%	79.9%	0.0%
2350	0.0%	74.5%	75.5%	76.3%	77.1%	77.7%	78.0%	78.3%	78.6%	78.8%	78.9%	79.1%	0.0%
2400	0.0%	73.3%	74.3%	75.2%	76.0%	76.8%	77.1%	77.3%	77.8%	78.1%	78.2%	78.3%	0.0%
2450	0.0%	72.0%	73.2%	74.2%	75.1%	75.8%	76.2%	76.5%	77.0%	77.3%	77.6%	77.6%	0.0%
2500	0.0%	70.7%	72.3%	73.5%	74.4%	75.1%	75.5%	75.8%	76.5%	76.9%	77.2%	77.3%	0.0%
2550	0.0%	68.5%	71.1%	72.5%	73.6%	74.4%	74.8%	75.2%	75.9%	76.4%	76.8%	77.0%	0.0%
2600	0.0%	66.0%	69.0%	71.2%	72.6%	73.7%	74.2%	74.6%	75.3%	75.9%	76.3%	76.7%	0.0%

**Kerr Turbine Efficiency Hill Curve (Refurbished Units 2010)**

Discharge (cfs)	Total Turbine-Generator Efficiency (%) vs. Head (ft)								
	0	35	51	54	56	58	61	80	999
0	0%	61.2%	76.5%	76.5%	76.7%	76.9%	76.9%	61.5%	0%
2000	0%	65.6%	83.8%	84.1%	84.4%	84.7%	84.7%	67.9%	0%
2500	0%	66.8%	85.3%	85.5%	85.8%	86.1%	86.2%	69.0%	0%
3000	0%	68.0%	86.7%	86.9%	87.2%	87.6%	87.7%	70.3%	0%
3500	0%	69.2%	88.1%	88.3%	88.7%	89.1%	89.1%	71.3%	0%
4000	0%	70.2%	89.4%	89.6%	89.9%	90.2%	90.1%	72.2%	0%
4500	0%	70.7%	90.0%	90.1%	90.4%	90.7%	90.7%	72.6%	0%
4750	0%	71.2%	90.5%	90.6%	90.9%	91.2%	91.2%	73.0%	0%
5000	0%	71.6%	90.9%	91.1%	91.3%	91.6%	91.6%	73.3%	0%
5250	0%	71.9%	91.3%	91.4%	91.7%	92.0%	91.9%	73.5%	0%
5500	0%	72.1%	91.4%	91.6%	91.9%	92.1%	92.0%	73.6%	0%
6000	0%	72.2%	91.4%	91.5%	91.7%	92.0%	91.9%	73.5%	0%
6500	0%	72.1%	91.0%	91.1%	91.3%	91.6%	91.5%	73.2%	0%
7000	0%	71.6%	90.2%	90.3%	90.6%	90.8%	90.7%	72.6%	0%
7500	0%	71.5%	89.8%	89.9%	90.2%	90.4%	90.3%	72.2%	0%
8500	0%	70.1%	87.9%	88.0%	88.2%	88.4%	88.2%	70.5%	0%
9000	0%	69.3%	87.0%	87.0%	87.2%	87.3%	87.2%	69.6%	0%


**Pensacola Dam Maximum Discharge (cfs) per Unit vs. Net HeadDischarge Limited by Cavitation - 6 Units Total**

Net Head (ft)	Max Discharge per Unit (cfs)	Max Discharge Total (cfs)
0	0	0
95	2005	12030
100	2100	12600
105	2193	13158
110	2284	13704
115	2372	14232
120	2450	14700
125	2505	15030
126	2480	14880
128	2380	14280
129	2310	13860
130	2220	13320
154.67	0	0
999.00	0	0



### Kerr Dam Maximum Discharge (cfs) per Unit vs. Net Head Discharge Limited by Cavitation - 4 Units Total

Net Head (ft)	Max Discharge per Unit (cfs)	Max Discharge Total (cfs)
0	8450	33800
51	8450	33800
55	8330	33320
58	8250	33000
61	7950	31800
140.50	0	0
999	0	0




### Pensacola Dam Tailwater Rating Curve

Discharge TW Elev  
(cfs) (ft PD)

0	623.37
10000	625.43
20000	627.42
30000	629.32
40000	631.15
50000	632.89
60000	634.56
70000	636.14
80000	637.65
90000	639.07
100000	640.41
110000	641.68
120000	642.86
130000	643.97
140000	644.99
150000	645.93
160000	646.80
170000	647.58
180000	648.28
190000	648.90
200000	649.45
210000	650.11
220000	650.69
230000	651.27
240000	651.84
250000	652.42
275000	653.86
300000	655.30
600000	672.61

Assumed Pensacola Dam Tailwater Rating Curve



## SAMPLE TURBINE-GENERATOR OUTAGE DATA

Plant	Unit No.	Outage Begin	Outage End	Plant	Unit No.	Outage Begin	Outage End	Plant	Unit No.	Outage Begin	Outage End
Pensacola	1	5/15/2003 13:00	5/15/2003 16:00	Pensacola	2	10/29/2014 16:05	10/29/2014 16:06	Pensacola	4	1/30/2013 13:22	1/30/2013 14:19
Pensacola	1	9/19/2004 5:00	10/3/2004 5:00	Pensacola	2	1/6/2015 7:40	1/6/2015 9:44	Pensacola	4	2/7/2013 9:43	2/7/2013 12:50
Pensacola	1	9/29/2004 7:00	10/3/2004 5:00	Pensacola	2	1/12/2015 9:43	1/26/2015 14:47	Pensacola	4	8/13/2013 15:10	8/13/2013 16:29
Pensacola	1	10/3/2004 5:00	10/6/2004 5:00	Pensacola	2	3/8/2015 7:23	3/8/2015 9:38	Pensacola	4	9/19/2013 6:05	9/19/2013 10:59
Pensacola	1	10/6/2004 5:00	10/15/2004 5:00	Pensacola	2	3/21/2015 14:03	3/21/2015 16:10	Pensacola	4	12/6/2013 18:00	12/7/2013 9:35
Pensacola	1	10/15/2004 5:00	2/1/2005 6:00	Pensacola	2	6/20/2015 18:40	6/20/2015 19:14	Pensacola	4	12/7/2013 9:35	12/7/2013 10:37
Pensacola	1	1/18/2005 6:00	2/15/2005 6:00	Pensacola	2	9/24/2015 15:35	9/24/2015 16:28	Pensacola	4	12/24/2013 9:46	12/24/2013 13:43
Pensacola	1	10/24/2005 5:00	10/25/2005 5:00	Pensacola	2	10/2/2015 17:11	10/2/2015 20:55	Pensacola	4	1/5/2015 5:30	1/5/2015 7:45
Pensacola	1	12/13/2005 23:00	12/16/2005 23:00	Pensacola	2	10/29/2015 9:08	10/30/2015 10:36	Pensacola	4	4/18/2015 15:21	4/18/2015 20:26
Pensacola	1	12/19/2005 6:00	12/20/2005 6:00	Pensacola	3	2/10/2003 6:00	3/1/2003 6:00	Pensacola	4	6/20/2015 18:40	6/20/2015 19:14
Pensacola	1	8/10/2006 5:00	8/15/2006 5:00	Pensacola	3	5/15/2003 13:00	5/17/2003 5:00	Pensacola	4	6/24/2015 10:44	6/24/2015 11:03
Pensacola	1	9/19/2006 12:00	9/22/2006 20:00	Pensacola	3	8/14/2003 5:00	8/15/2003 5:00	Pensacola	4	9/24/2015 15:35	9/24/2015 16:27
Pensacola	1	9/25/2006 20:00	9/27/2006 5:00	Pensacola	3	8/23/2003 5:00	8/28/2003 5:00	Pensacola	4	10/2/2015 15:30	10/2/2015 20:55
Pensacola	1	9/27/2006 12:00	10/2/2006 5:00	Pensacola	3	12/1/2003 6:00	3/1/2004 6:00	Pensacola	5	1/24/2003 15:00	2/3/2003 22:00
Pensacola	1	9/27/2006 14:00	10/2/2006 5:00	Pensacola	3	6/10/2004 5:00	6/14/2004 5:00	Pensacola	5	11/6/2004 13:24	11/8/2004 22:00
Pensacola	1	10/3/2006 13:00	10/5/2006 5:00	Pensacola	3	9/2/2004 5:00	9/5/2004 5:00	Pensacola	5	12/13/2005 23:00	12/16/2005 23:00
Pensacola	1	10/5/2006 5:00	10/6/2006 5:00	Pensacola	3	9/9/2004 13:00	9/10/2004 21:00	Pensacola	5	12/17/2005 6:00	12/20/2005 6:00
Pensacola	1	10/6/2006 5:00	10/8/2006 5:00	Pensacola	3	5/31/2005 17:00	6/1/2005 21:00	Pensacola	5	8/10/2006 5:00	8/15/2006 5:00
Pensacola	1	11/28/2006 18:00	12/31/2006 6:00	Pensacola	3	6/1/2005 21:00	6/2/2005 17:00	Pensacola	5	9/19/2006 12:00	9/22/2006 20:00
Pensacola	1	3/14/2007 13:00	3/15/2007 4:00	Pensacola	3	12/13/2005 23:00	12/16/2005 23:00	Pensacola	5	9/25/2006 20:00	9/27/2006 5:00
Pensacola	1	3/14/2007 19:00	3/15/2007 4:00	Pensacola	3	12/17/2005 6:00	12/20/2005 6:00	Pensacola	5	9/27/2006 12:00	10/2/2006 5:00
Pensacola	1	3/15/2007 14:00	3/17/2007 19:00	Pensacola	3	2/27/2006 6:00	3/4/2006 6:00	Pensacola	5	9/27/2006 14:00	10/2/2006 5:00
Pensacola	1	8/23/2007 5:00	8/25/2007 5:00	Pensacola	3	8/10/2006 5:00	8/15/2006 5:00	Pensacola	5	10/3/2006 13:00	10/5/2006 5:00
Pensacola	1	9/26/2007 13:00	9/29/2007 5:00	Pensacola	3	9/19/2006 12:00	9/22/2006 20:00	Pensacola	5	10/5/2006 5:00	10/6/2006 5:00
Pensacola	1	11/13/2007 18:00	11/15/2007 6:00	Pensacola	3	9/25/2006 20:00	9/27/2006 5:00	Pensacola	5	10/6/2006 5:00	10/8/2006 5:00
Pensacola	1	3/26/2008 20:08	3/29/2008 4:00	Pensacola	3	9/27/2006 12:00	10/2/2006 5:00	Pensacola	5	11/28/2006 18:00	12/31/2006 6:00
Pensacola	1	3/27/2008 12:00	3/29/2008 4:00	Pensacola	3	9/27/2006 14:00	10/2/2006 5:00	Pensacola	5	1/4/2007 16:00	3/4/2007 6:00
Pensacola	1	10/27/2009 13:00	1/30/2010 6:00	Pensacola	3	10/3/2006 13:00	10/5/2006 5:00	Pensacola	5	3/14/2007 19:00	3/15/2007 4:00
Pensacola	1	4/20/2010 5:00	4/30/2010 5:00	Pensacola	3	10/3/2006 13:02	10/5/2006 5:00	Pensacola	5	4/12/2007 13:11	4/17/2007 5:00
Pensacola	1	6/25/2010 11:00	6/25/2010 12:00	Pensacola	3	10/5/2006 5:00	10/6/2006 5:00	Pensacola	5	2/4/2008 15:10	2/5/2008 20:30
Pensacola	1	6/28/2010 11:00	6/28/2010 12:00	Pensacola	3	10/6/2006 5:00	10/8/2006 5:00	Pensacola	5	3/29/2008 18:15	4/2/2008 4:00
Pensacola	1	9/9/2010 20:25	9/10/2010 17:00	Pensacola	3	11/28/2006 18:00	12/31/2006 6:00	Pensacola	5	3/31/2008 12:00	4/2/2008 4:00
Pensacola	1	7/26/2011 17:05	7/31/2011 5:00	Pensacola	3	3/8/2007 5:00	3/8/2007 18:00	Pensacola	5	12/19/2008 6:00	1/31/2009 6:00
Pensacola	1	10/25/2011 15:02	12/31/2012 23:59	Pensacola	3	3/14/2007 13:00	3/15/2007 4:00	Pensacola	5	6/25/2010 11:00	6/25/2010 18:00
Pensacola	1	10/25/2011 15:02	12/31/2013 22:02	Pensacola	3	3/14/2007 19:00	3/15/2007 4:00	Pensacola	5	12/13/2010 12:00	3/11/2011 22:00
Pensacola	1	11/22/2011 8:10	11/23/2011 0:00	Pensacola	3	3/15/2007 14:00	3/17/2007 19:00	Pensacola	5	9/12/2011 18:25	10/1/2011 5:00
Pensacola	1	12/13/2011 8:00	12/13/2011 11:00	Pensacola	3	3/12/2008 15:00	3/14/2008 14:00	Pensacola	5	10/25/2011 15:02	12/31/2012 23:59
Pensacola	1	12/19/2011 8:00	12/19/2011 10:00	Pensacola	3	1/7/2009 13:32	3/1/2009 20:00	Pensacola	5	10/25/2011 15:02	12/31/2013 22:02
Pensacola	1	12/20/2011 9:31	12/21/2011 16:00	Pensacola	3	1/7/2009 14:00	3/1/2009 20:00	Pensacola	5	12/8/2011 14:00	12/8/2011 17:00
Pensacola	1	12/23/2011 9:19	12/23/2011 16:00	Pensacola	3	6/25/2010 11:00	6/25/2010 12:00	Pensacola	5	1/17/2012 10:30	1/18/2012 16:00
Pensacola	1	2/28/2012 8:11	3/6/2012 8:00	Pensacola	3	8/10/2010 12:00	8/17/2010 21:00	Pensacola	5	1/20/2012 11:39	1/20/2012 16:00
Pensacola	1	3/21/2012 13:05	3/22/2012 16:00	Pensacola	3	8/1/2011 12:38	8/5/2011 21:00	Pensacola	5	1/23/2012 14:47	1/24/2012 12:00
Pensacola	1	4/5/2012 9:05	4/5/2012 10:00	Pensacola	3	8/1/2011 13:00	8/5/2011 21:00	Pensacola	5	7/24/2012 12:28	7/25/2012 16:00
Pensacola	1	4/20/2012 13:30	4/20/2012 16:00	Pensacola	3	10/25/2011 15:02	12/31/2012 23:59	Pensacola	5	8/21/2012 13:16	8/21/2012 16:00
Pensacola	1	4/27/2012 9:41	4/27/2012 12:00	Pensacola	3	10/25/2011					

### Pensacola Dissolved Oxygen Air Valve Data

